FURTHER INFORMATION RECEIVED/VALIDATED APPLICATIONS

FROM 08/07/2019 TO 12/07/2019

The use of the personal details of planning applicants, including for marketing purposes, maybe unlawful under the Data Protection Acts 1988 - 2003 and may result in action by the Data Protection Commissioner, against the sender, including prosecution.

an existing agricultural site entrance; approximately 200m of underground cabling and all associated site development and reinstatement works in the townland of Luppan, County Monagha and (ii) the installation of approximately 22km of 38kV electricity cables from the proposed substation to the existing electricity substation in the townland of Lisdrumdoagh, County Monaghan. The electricity cables will comprise approximately 17km of overher line and approximately 5 km of underground line. Overhead lines	FILE NUMBER	APPLICANTS NAME	APP. TYPE	DATE INVALID	DATE RECEI VED	DEVELOPMENT DESCRIPTION AND LOCATION
maximum height of 16 metres, and all associated site developmen and reinstatement works. Underground cables will be located with private lands and within the public roads numbered L5171, L1400 and L1171; will be installed in excavated trenches of approximate 1.2m in depth and will include associated underground ducting, joint bays, communication chamber bays, sheath link boxes and inspection chambers; directional drilling beneath the N12 and Uls Canal and all associated site development and reinstatement wor A vehicle access track of up to 4m in width will be provided immediately adjacent to underground cables with private lands. This planning application is accompanied by an Environmental Impact Assessment Report which includes an assessment of the likely impacts of the proposed development, as a whole and in combination with the relevant off-site or secondary developments which will occur as a direct result of the proposed development, including the wind farm development permitted pursuant to	18/562		Ρ		11/07/2019	switchroom and equipment compound with palisade fence; the construction of approximately 400m of site access track and the upgrading of approximately 150m of existing agricultural track and an existing agricultural site entrance; approximately 200m of underground cabling and all associated site development and reinstatement works in the townland of Luppan, County Monaghan; and (ii) the installation of approximately 22km of 38kV electricity cables from the proposed substation to the existing electricity substation in the townland of Lisdrumdoagh, County Monaghan. The electricity cables will comprise approximately 17km of overhead line and approximately 5 km of underground line. Overhead lines will consist of 3 no. cables suspended from wooden poles with a maximum height of 16 metres, and all associated site development and reinstatement works. Underground cables will be located within private lands and within the public roads numbered L5171, L1400 and L1171; will be installed in excavated trenches of approximately 1.2m in depth and will include associated underground ducting, joint bays, communication chamber bays, sheath link boxes and inspection chambers; directional drilling beneath the N12 and Ulster Canal and all associated site development and reinstatement works. A vehicle access track of up to 4m in width will be provided immediately adjacent to underground cables with private lands. This planning application is accompanied by an Environmental Impact Assessment Report which includes an assessment of the likely impacts of the proposed development, as a whole and in combination with the relevant off-site or secondary developments which will occur as a direct result of the proposed development,

MONAGHAN COUNTY COUNCIL

TIME : 10:58:32 PAGE : 2

PLANNING APPLICATIONS FURTHER INFORMATION RECEIVED/VALIDATED APPLICATIONS

FROM 08/07/2019 TO 12/07/2019

The use of the personal details of planning applicants, including for marketing purposes, maybe unlawful under the Data Protection Acts 1988 - 2003 and may result in action by the Data Protection Commissioner, against the sender, including prosecution.

FILE		APP.	DATE	DATE	
NUMBER	APPLICANTS NAME	TYPE	INVALID	RECEIVED	DEVELOPMENT DESCRIPTION AND LOCATION

19/118	Tru Beginnings Community Playgroup LTD	R	11/07/2019	 F Permission to retain a single storey nursery building, existing connection to wastewater treatment system & associated works. Significant Further Information relates to revised site layout and documentation in relation to existing wastewater treatment system Drumbirn TD Clara Emyvale Amount Amount Amoun
				Co.Monaghan

MONAGHAN COUNTY COUNCIL

PLANNING APPLICATIONS FURTHER INFORMATION RECEIVED/VALIDATED APPLICATIONS

FROM 08/07/2019 TO 12/07/2019

The use of the personal details of planning applicants, including for marketing purposes, maybe unlawful under the Data Protection Acts 1988 - 2003 and may result in action by the Data Protection Commissioner, against the sender, including prosecution.

FILE NUMBER	APPLICANTS NAME	APP. TYPE	DATE INVALID	DATE RECEIVED		DEVELOPMENT DESCRIPTION AND LOCATION
19/195	Richard Moore	Ρ		12/07/2019	F	permission to construct a new dairy facility & also provide an extension to existing agricultural building within existing farmyard complex together with all ancillary site works. Significant further information received Derrins Td. Drum Co. Monaghan

Total: 3

*** END OF REPORT **