

Test Report

Report of: Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

Report to: Monaghan County Council

Report date: 24/03/14

Location sampled: Carrickmacross P.W.S

Date collected: 17/02/2014

Date received: 17/02/2014

Analysis group: DW AUDIT

Comments:

			Laboratory Ref:	1410406
			Type of sample:	Drinking Water
			Sampling point:	Public Main, Ballybay Rd Junction, Carrickmacross
			Sampled by:	Dermot McCague
			Time Sampled:	nt
			Start/End - Dates of Analysis:	18-02-14/18-03-14
			Grid Ref:	284181 304564
			Status of results:	Final
Parameter	Units	Limits		
F **	Residual Chlorine	mg/l Cl		0.32
F **	Taste			ATC
F **	Odour			nd
W0 g	pH	pH	> 6.5 And < 9.5	7.5
B12	True Colour	Hazen		10
W0 g	Conductivity @25°C	µS/cm @ 25	< 2760	569
W0 g	Conductivity @20°C	µS/cm @ 20	< 2500	515
**	Coliform Bacteria	No/100 ml	0	0
**	E. Coli	No/100 ml	0	0
**	Clostridia Perfringens	No/100ml	0	0
**	Heterotrophic plate count @ 22°C	No/ml		0
**	Enterococci	No/100ml	0	0
W0 7	Chloride	mg/l Cl	< 250	17
W0 7	Ammonia	mg/l NH4	< 0.3	<0.026
W0 7	Nitrite (as NO2)	mg/l NO2	< 0.49	<0.0132
W0 7	Ortho-phosphate (as P2O5)	µg/l P2O5	< 5000	41
W0 7	Total Oxidised Nitrogen (as NO3)	mg/l NO3	< 50	22
W0 7	Nitrate (as NO3)	mg/l NO3	< 50	23
**	Bromate	ug/l	< 10	0.3
**	Cyanide	mg/l CN	< 0.05	<0.01
B10	Fluoride	mg/l F	< 0.8	0.79
B6	Total Hardness (as Ca)	mg/l Ca		108
B10	Sulphate	mg/l SO4	< 250	12.6
**	Total Organic Carbon	mg/l C		<1.5
B14	Turbidity	NTU		0.5
B14	Turbidity - Works	NTU		0.6

Laboratory Ref:	1410406
Type of sample:	Drinking Water
Sampling point:	Public Main, Ballybay Rd Junction, Carrickmacross
Sampled by:	Dermot McCague
Time Sampled:	nt
Start/End - Dates of Analysis:	18-02-14/18-03-14
Grid Ref:	284181 304564
Status of results:	Final

Parameter	Units	Limits	
** Boron	µg/l	< 1000	11
** Sodium	mg/l	< 200	10
** Aluminium	µg/l	< 200	11
** Chromium	µg/l	< 50	1.3
** Iron	µg/l	< 200	13
** Manganese	µg/l	< 50	<5.0
** Nickel	µg/l	< 20	<1.0
** Copper	mg/l	< 2	0.01
** Arsenic	µg/l	< 10	<1.0
** Selenium	µg/l	< 10	<1.0
** Cadmium	µg/l	< 5	0.02
** Lead	µg/l	< 25	8
** Antimony	µg/l	< 5	<1.0
** Mercury	µg/l		<0.050
B15 Benzene	ug/l	< 1	<0.60
** Benzo(a)pyrene	ug/l	< 0.01	<0.001
** Total PAH	ug/l	< 0.1	0.009
** Total Pesticides	ug/l	< 0.5	<0.011
B15 1,2-Dichloroethane	ug/l	< 3	<0.60
B15 Trichloroethene	ug/l		<0.20
B15 Tetrachloroethene	ug/l		<0.70
B15 Tetrachloroethane+Trichloroethene	µg/l	< 10	<0.7
B.1 E Bromodichloromethane	µg/l		<0.7
B.1 E Bromoform	µg/l		0.8
B.1 E Chloroform	µg/l		<0.6
B.1 E Dibromochloromethane	µg/l		1.1
B.1 E Total Trihalomethanes	µg/l	< 100	2.5

- | | |
|--|--|
| 1) Results highlighted and in bold exceed specified limits. | 8) tntc "Too numerous to count" |
| 2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document. | 9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported. |
| 3) All metals analysed in EPA Richview Laboratory.
All Total Nitrogens analysed in EPA Kilkenny Laboratory.
PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd. | 10) F "Field measured parameters" |
| 4) nm "Not measured" | 11) "*" indicates paramters/results produced from non-accredited analytical methods. |
| 5) nd "None detected" | 12) Test Reports relate only to the samples tested and as described on report form. |
| 6) nt "No time" - Time not recorded | 13) Test Reports shall not be reproduced, except in full, without the consent of the EPA. |
| 7) nr "Not reported" | 14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation. |
| | 15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms. |
| | 16) ATC = Acceptable To Consumers |

Signed:

Ray Smith

Date:

24/Mar/2014

Ray Smith
Regional Manager,
EPA
Monaghan