

Test Report

Report of: Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

Report to: Monaghan County Council

Report date: 20/12/13

Location sampled: Churchill/Oram

Date collected: 09/09/2013

Date received: 09/09/2013

Analysis group: CHECK

Comments:

| | | | Laboratory Ref: | 1303706 |
|-----------|------------------------|------------|---------------------------------------|--------------------|
| | | | Type of sample: | Drinking Water |
| | | | Sampling point: | O'Neill, Corrintra |
| | | | Sampled by: | Dermot McCague |
| | | | Time Sampled: | nt |
| | | | Start/End - Dates of Analysis: | 10-09-13/06-12-13 |
| | | | Grid Ref: | 281650 325085 |
| | | | Status of results: | Final |
| Parameter | Units | Limits | | |
| F ** | Taste | | | ATC |
| F ** | Odour | | | nd |
| F ** | Residual Chlorine | mg/l Cl | | 0.06 |
| B12 | True Colour | Hazen | | 9 |
| B4 | Conductivity @25°C | µS/cm @ 25 | < 2760 | 382 |
| B7 | pH | pH | > 6.5 And < 9.5 | 7.5 |
| B17 | Ammonia | mg/l NH4 | < 0.3 | <0.04 |
| B14 | Turbidity | NTU | | <0.5 |
| ** | Aluminium | µg/l | < 200 | <10 |
| ** | Iron | µg/l | < 200 | <10 |
| ** | Manganese | µg/l | < 50 | <5 |
| ** | Lead | µg/l | < 25 | <1 |
| ** | Coliform Bacteria | No/100 ml | 0 | 0 |
| ** | E. Coli | No/100 ml | 0 | 0 |
| ** | Clostridia Perfringens | No/100ml | 0 | 0 |
| B4 | Conductivity @20°C | µS/cm @ 20 | < 2500 | 346 |

- | | |
|--|--|
| 1) Results highlighted and in bold exceed specified limits. | 8) tntc "Too numerous to count" |
| 2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document. | 9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported. |
| 3) All metals analysed in EPA Richview Laboratory PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd. | 10) F "Field measured parameters" |
| 4) measured" | 11) "*" indicates paramters/results produced from non-accredited analytical methods. |
| 5) nd "None detected" | 12) Test Reports relate only to the samples tested and as described on report form. |
| 6) nt "No time" - Time not recorded | 13) Test Reports shall not be reproduced, except in full, without the consent of the EPA. |
| 7) "Not reported" | 14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation. |
| | 15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms. |
| | 16) ATC = Acceptable To Consumers |

Signed: Ray Smith

Date: 20/Dec/2013

Ray Smith
Regional Manager,
EPA
Monaghan