

Environmental Protection Agency Regional Inspectorate The Glen, Monaghan



Test Report

Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)]. Report of:

Monaghan County Council Report to:

Report date: 11/12/14

Location sampled: Churchill/Oram

11/11/2014 Date collected: Date received: 11/11/2014

Analysis group: CHECK

Comments:

			Laboratory Ref:	1414124
Type of sample:			Drinking Water	
Sampling point:				Art Mooney Centre, Oram
Sampled by:				Dermot McCague
Time Sampled:				nt
		12-11-14/21-11-14		
Start/End - Dates of Analysis: Grid Ref:				285279 322595
Status of results:				Final
Parameter Units Limits			i iliai	
F	Taste	Oo	Lillito	ATC
** F	Odour			nd
** F	Residual Chlorine	mg/l Cl		0.09
**	True Colour	Hazen		7
	Conductivity @25°C	μS/cm @ 25	< 2760	294
<u> </u>		·		7.8
	pH	pH	> 6.5 And < 9.5	
L	Ammonia	mg/l NH4	< 0.3	<0.026
	Turbidity	NTU		<0.5
**	Boron	μg/l	< 1000	14
	Sodium	mg/l	< 200	21
**	Aluminium	μg/l	< 200	<10.0
**	Chromium	μg/l	< 50	<1.0
**	Iron	μg/l	< 200	<10.0
**	Manganese	μg/l	< 50	<5.0
**	Nickel	μg/l	< 20	3.2
**	Copper	mg/l	< 2	0.03
**	Arsenic	μg/l	< 10	<1.0
**	Selenium	μg/l	< 10	<1.0
**	Cadmium	μg/l	< 5	0.05
**	Lead	μg/l	< 25	<1.0
**	Antimony	μg/l	< 5	<1.0
**	Coliform Bacteria	No/100 ml	0	0
**	E. Coli	No/100 ml	0	0
**	Clostridia Perfringens	No/100ml	0	0
	Conductivity @20°C	μS/cm @ 20	< 2500	266

- Results highlighted and in bold exceed specified limits. Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document.
- All metals analysed in EPA Richview Laboratory. All Total Nitrogens analysed in EPA Kilkenny Laboratory. PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd.
- nm "Not measured"
- 5) nd
- "None detected"
 "No time" Time not recorded
 "Not reported" 6) 7) nt
- nr

- tntc "Too numerous to count" fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported. 9)
- 10)
- F "Field measured parameters"

 *** indicates parameters/results produced from non-accredited analytical 11)
- Test Reports relate only to the samples tested and as described on report
- Test Reports shall not be reproduced, except in full, without the consent of the EPA. 13)
- The laboratory is accredited by the INAB only for the parameters listed in 14) the scope of Accreditation.

 Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms.
- 15)
- 16) ATC = Acceptable To Consumers

Ray Santo Signed:

> Ray Smith Regional Manager, EPĂ

Monaghan

11/Dec/2014 Date: