

Environmental Protection Agency Regional Inspectorate The Glen, Monaghan



Test Report

Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)]. Report of:

Monaghan County Council Report to:

Report date: 16/07/15

Location sampled: Churchill/Oram

Date collected: 22/06/2015 Date received: 22/06/2015

Analysis group: **CHECK**

Comments:

	minicino.		Laboratory Ref:	1512112
	Type of sample:			Drinking Water
Sampling point:				2 Sruth An Iuir
		Z Gradi / di Tali		
Sampled by: Time Sampled: Start/End - Dates of Analysis: Grid Ref:				Dermot McCague
				nt
				23-06-15/07-07-15
				285084 322830
Status of results:				Final
			Finai	
		Units	Limits	
F **	Taste			ATC
F **	Odour			nd
F **	Residual Chlorine	mg/l Cl		0.07
	True Colour	Hazen		<5
	Conductivity @25°C	μS/cm @ 25	< 2760	323
	рН	рН	> 6.5 And < 9.5	7.6
	Ammonia	mg/l NH4	< 0.3	<0.026
	Turbidity	NTU		<0.50
**	Coliform Bacteria	No/100 ml	0	0
**	E. Coli	No/100 ml	0	0
**	Clostridia Perfringens	No/100ml	0	0
	Conductivity @20°C	μS/cm @ 20	< 2500	292
	Aluminium	μg/l	< 200	<10.0
	Iron	μg/l	< 200	<10.0
	Manganese	μg/l	< 50	<5.0
	Lead	μg/l	< 10	<1.0

- Results highlighted and in bold exceed specified limits. Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document.
- All metals analysed in EPA Richview Laboratory. All Total Nitrogens analysed in EPA Kilkenny Laboratory. PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd.
- nm "Not measured"
- 5) nd
- "None detected"
 "No time" Time not recorded
 "Not reported" 6) 7) nt
- nr

- tntc "Too numerous to count" fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported. 9)
- 10)
- F "Field measured parameters"

 *** indicates parameters/results produced from non-accredited analytical 11)
- Test Reports relate only to the samples tested and as described on report
- Test Reports shall not be reproduced, except in full, without the consent of the EPA. 13)
- The laboratory is accredited by the INAB only for the parameters listed in 14) the scope of Accreditation.
 Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms.
- 15)
- 16) ATC = Acceptable To Consumers

Signed: PP Regina Mª Gan

Ray Smith Regional Manager,

EPA

Monaghan

16/Jul/2015 Date: