

Test Report

Report of: Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

Report to: Monaghan County Council

Report date: 22/12/14

Location sampled: Clones P.W.S

Date collected: 08/12/2014

Date received: 08/12/2014

Analysis group: CHECK

Comments:

			Laboratory Ref:	1414440
			Type of sample:	Drinking Water
			Sampling point:	Town Council Offices, Clones
			Sampled by:	John Quinn
			Time Sampled:	nt
			Start/End - Dates of Analysis:	09-12-14/18-12-14
			Grid Ref:	250270 317245
			Status of results:	Final
Parameter	Units	Limits		
F ** Taste			nm	
F ** Odour			nm	
F ** Residual Chlorine	mg/l Cl		0.1	
True Colour	Hazen		5	
Conductivity @25°C	µS/cm @ 25	< 2760	640	
pH	pH	> 6.5 And < 9.5	7.7	
Ammonia	mg/l NH4	< 0.3	<0.026	
Turbidity	NTU		<0.5	
** Aluminium	µg/l	< 200	45	
** Iron	µg/l	< 200	<10.0	
** Manganese	µg/l	< 50	<5.0	
** Lead	µg/l	< 10	<1.0	
** Coliform Bacteria	No/100 ml	0	0	
** E. Coli	No/100 ml	0	0	
** Clostridia Perfringens	No/100ml	0	0	
Conductivity @20°C	µS/cm @ 20	< 2500	579	

- 1) Results highlighted and in bold exceed specified limits.
- 2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document.
- 3) All metals analysed in EPA Richview Laboratory.
All Total Nitrogens analysed in EPA Kilkenny Laboratory.
PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd.
- 4) nm "Not measured"
- 5) nd "None detected"
- 6) nt "No time" - Time not recorded
- 7) nr "Not reported"
- 8) tntc "Too numerous to count"
- 9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported.
- 10) F "Field measured parameters"
- 11) *** indicates paramters/results produced from non-accredited analytical methods.
- 12) Test Reports relate only to the samples tested and as described on report form.
- 13) Test Reports shall not be reproduced, except in full, without the consent of the EPA.
- 14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation.
- 15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms.
- 16) ATC = Acceptable To Consumers

Signed: _____



Ray Smith
Regional Manager,
EPA
Monaghan

Date: _____

22/Dec/2014