

Test Report

Report of: Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

Report to: Monaghan County Council

Report date: 19/06/14

Location sampled: Clones P.W.S

Date collected: 28/04/2014

Date received: 28/04/2014

Analysis group: DW Audit

Comments:

			Laboratory Ref:	1410943
			Type of sample:	Drinking Water
			Sampling point:	Town Council Offices, Clones
			Sampled by:	John Quinn
			Time Sampled:	nt
			Start/End - Dates of Analysis:	29-04-14/16-06-14
			Grid Ref:	250270 317345
			Status of results:	Final
Parameter	Units	Limits		
F **	Residual Chlorine	mg/l Cl		0.6
F **	Taste			ATC
F **	Odour			nd
W0 9	pH	pH	> 6.5 And < 9.5	7.4
B12	True Colour	Hazen		<5
W0 8	Conductivity @25°C	µS/cm @ 25	< 2760	640
W0 8	Conductivity @20°C	µS/cm @ 20	< 2500	579
**	Coliform Bacteria	No/100 ml	0	0
**	E. Coli	No/100 ml	0	0
**	Clostridia Perfringens	No/100ml	0	0
**	Heterotrophic plate count @ 22°C	No/ml		0
**	Enterococci	No/100ml	0	0
W0 7	Chloride	mg/l Cl	< 250	17
W0 7	Ammonia	mg/l NH4	< 0.3	<0.026
W0 7	Nitrite (as NO2)	mg/l NO2	< 0.49	<0.0132
W0 7	Ortho-phosphate (as P2O5)	µg/l P2O5	< 5000	<23
W0 7	Total Oxidised Nitrogen (as NO3)	mg/l NO3	< 50	5.6
W0 7	Nitrate (as NO3)	mg/l NO3	< 50	5.7
**	Bromate	ug/l	< 10	<0.1
**	Cyanide	mg/l CN	< 0.05	<0.01
B10	Fluoride	mg/l F	< 0.8	<0.150
B6	Total Hardness (as Ca)	mg/l Ca		136
B10	Sulphate	mg/l SO4	< 250	66.5
**	Total Organic Carbon	mg/l C		3.0
B14	Turbidity	NTU		0.5
B14	Turbidity - Works	NTU		0.7

Laboratory Ref:	1410943
Type of sample:	Drinking Water
Sampling point:	Town Council Offices, Clones
Sampled by:	John Quinn
Time Sampled:	nt
Start/End - Dates of Analysis:	29-04-14/16-06-14
Grid Ref:	250270 317345
Status of results:	Final

Parameter	Units	Limits	
** Boron	µg/l	< 1000	23
** Sodium	mg/l	< 200	9.4
** Aluminium	µg/l	< 200	87
** Chromium	µg/l	< 50	<1.0
** Iron	µg/l	< 200	15
** Manganese	µg/l	< 50	34
** Nickel	µg/l	< 20	<1.0
** Copper	mg/l	< 2	0.03
** Arsenic	µg/l	< 10	<1.0
** Selenium	µg/l	< 10	<1.0
** Cadmium	µg/l	< 5	0.02
** Lead	µg/l	< 25	1.4
** Antimony	µg/l	< 5	<1.0
** Mercury	µg/l		<0.050
B15 Benzene	ug/l	< 1	<0.60
** Benzo(a)pyrene	ug/l	< 0.01	<0.001
** Total PAH	ug/l	< 0.1	<0.001
** Total Pesticides	ug/l	< 0.5	<0.011
B15 1,2-Dichloroethane	ug/l	< 3	<0.60
B15 Trichloroethene	ug/l		<0.20
B15 Tetrachloroethene	ug/l		<0.70
B15 Tetrachloroethane+Trichloroethene	µg/l	< 10	<0.7
B.1 Bromodichloromethane	µg/l		9.6
B.1 Bromoform	µg/l		<0.6
B.1 Chloroform	µg/l		14.9
B.1 Dibromochloromethane	µg/l		3.1
B.1 Total Trihalomethanes	µg/l	< 100	27.7

- | | |
|--|--|
| 1) Results highlighted and in bold exceed specified limits. | 8) tntc "Too numerous to count" |
| 2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document. | 9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported. |
| 3) All metals analysed in EPA Richview Laboratory. All Total Nitrogens analysed in EPA Kilkenny Laboratory. PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd. | 10) F "Field measured parameters" |
| 4) nm "Not measured" | 11) "***" indicates paramters/results produced from non-accredited analytical methods. |
| 5) nd "None detected" | 12) Test Reports relate only to the samples tested and as described on report form. |
| 6) nt "No time" - Time not recorded | 13) Test Reports shall not be reproduced, except in full, without the consent of the EPA. |
| 7) nr "Not reported" | 14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation. |
| | 15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms. |
| | 16) ATC = Acceptable To Consumers |

Signed:

Ray Smith

Date:

19/Jun/2014

Ray Smith
Regional Manager,
EPA
Monaghan