

Environmental Protection Agency Regional Inspectorate The Glen, Monaghan



Test Report

Report of: Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

Report to: Monaghan County Council

Report date: 12/03/15

Lc	ocation sampled	: Corduff G.W.S		
Date collected:		10/02/2015	Date received:	10/02/2015
Analysis group:		CHECK		
	omments:			
			Laboratory Ref:	1510414
			Type of sample:	Drinking Water
			Sampling point:	3 The Grove, Corduff
			Sampled by:	Dermot McCague
			Time Sampled:	nt
Start/End - Dates of Analysis:			11-02-15/25-02-15	
	Grid Ref:		277514 307572	
			Status of results:	Final
Parameter		Units	Limits	
F **	Taste			ATC
F **	Odour			nd
F **	Residual Chlorine	mg/l Cl		0.29
	True Colour	Hazen		10
	Conductivity @25°C	µS/cm @ 25	< 2760	220
	рН	рН	> 6.5 And < 9.5	7.4
	Ammonia	mg/l NH4	< 0.3	<0.026
	Turbidity	NTU		<0.5
**	Aluminium	µg/l	< 200	<10.0
**	Iron	µg/l	< 200	18
**	Manganese	µg/l	< 50	<5.0
**	Lead	µg/l	< 10	<1.0
**	Coliform Bacteria	No/100 ml	0	0
**	E. Coli	No/100 ml	0	0
**	Clostridia Perfringens	No/100ml	0	0
	Conductivity @20°C	µS/cm @ 20	< 2500	199

- 1) 2)
- Results highlighted and in bold exceed specified limits. Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a 9) separate document. 10)
- All metals analysed in EPA Richview Laboratory. 3) All Total Nitrogens analysed in EPA Kilkenny Laboratory. PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd.
- 4) nm "Not measured"
- 5) nd
- "None detected" "No time" Time not recorded "Not reported" 6) 7) nt
- nr

- 8)
- tntc "Too numerous to count" fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported.
- F "Field measured parameters" ***' indicates parameters/results produced from non-accredited analytical 11)
- 12) Test Reports relate only to the samples tested and as described on report form.
- Test Reports shall not be reproduced, except in full, without the consent of 13) the EPA.
- The laboratory is accredited by the INAB only for the parameters listed in 14) the scope of Accreditation. Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms.
- 15) 16)
 - ATC = Acceptable To Consumers

Signed:

Ray Santo

Date:

12/Mar/2015

Ray Smith Regional Manager, EPĂ Monaghan