

Test Report

Report of: **Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].**

Report to: **Monaghan County Council**

Report date: **24/06/14**

Location sampled: **Doohamlet G.W.S**

Date collected: 09/06/2014

Date received: 09/06/2014

Analysis group: C1C

Comments:

Parameter	Units	Limits	1411408	1411409
F ** Residual Chlorine	mg/l Cl		<0.05	<0.05
** Coliform Bacteria	No/100 ml	0	59	0
** E. Coli	No/100 ml	0	0	0
** Clostridia Perfringens	No/100ml	0	0	0

- 1) Results highlighted and in bold exceed specified limits.
- 2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document.
- 3) All metals analysed in EPA Richview Laboratory. All Total Nitrogens analysed in EPA Kilkenny Laboratory. PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd.
- 4) nm "Not measured"
- 5) nd "None detected"
- 6) nt "No time" - Time not recorded
- 7) nr "Not reported"
- 8) tntc "Too numerous to count"
- 9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported.
- 10) F "Field measured parameters"
- 11) *** indicates paramters/results produced from non-accredited analytical methods.
- 12) Test Reports relate only to the samples tested and as described on report form.
- 13) Test Reports shall not be reproduced, except in full, without the consent of the EPA.
- 14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation.
- 15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms.
- 16) ATC = Acceptable To Consumers

Signed: 

Date: 24/Jun/2014

Ray Smith
 Regional Manager,
 EPA
 Monaghan