

Test Report

Report of: Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

Report to: Monaghan County Council

Report date: 07/05/15

Location sampled: Lough Egish R.W.S.S

Date collected: 14/04/2015

Date received: 14/04/2015

Analysis group: CHECK

Comments:

Laboratory Ref: 1511071 Type of sample: Drinking Water Sampling point: McFadden, Rockcorry Sampled by: John Quinn Time Sampled: nt Start/End - Dates of Analysis: 15-04-15/30-04-15 Grid Ref: 264501 318986 Status of results: Final			
Parameter	Units	Limits	
F ** Taste			ATC
F ** Odour			nd
F ** Residual Chlorine	mg/l Cl		0.08
True Colour	Hazen		<5
Conductivity @25°C	µS/cm @ 25	< 2760	277
pH	pH	> 6.5 And < 9.5	7.8
Ammonia	mg/l NH4	< 0.3	<0.026
Turbidity	NTU		<0.50
** Coliform Bacteria	No/100 ml	0	0
** E. Coli	No/100 ml	0	0
** Clostridia Perfringens	No/100ml	0	0
Conductivity @20°C	µS/cm @ 20	< 2500	251
Aluminium	µg/l	< 200	58
Iron	µg/l	< 200	<10.0
Manganese	µg/l	< 50	7.1
Lead	µg/l	< 10	<1.0
** Enterococci	No/100ml		0

- | | |
|--|---|
| <p>1) Results highlighted and in bold exceed specified limits.</p> <p>2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document.</p> <p>3) All metals analysed in EPA Richview Laboratory.
All Total Nitrogens analysed in EPA Kilkenny Laboratory.
PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd.</p> <p>4) nm "Not measured"</p> <p>5) nd "None detected"</p> <p>6) nt "No time" - Time not recorded</p> <p>7) nr "Not reported"</p> | <p>8) tntc "Too numerous to count"</p> <p>9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported.</p> <p>10) F "Field measured parameters"</p> <p>11) *** indicates paramters/results produced from non-accredited analytical methods.</p> <p>12) Test Reports relate only to the samples tested and as described on report form.</p> <p>13) Test Reports shall not be reproduced, except in full, without the consent of the EPA.</p> <p>14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation.</p> <p>15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms.</p> <p>16) ATC = Acceptable To Consumers</p> |
|--|---|

Signed: PP Regina M.S. Ginn

Date: 07/May/2015

Ray Smith
Regional Manager,
EPA
Monaghan