

Test Report

Report of: Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

Report to: Monaghan County Council

Report date: 28/09/15

Location sampled: Lough Egish R.W.S.S

Date collected: 31/08/2015

Date received: 31/08/2015

Analysis group: CHECK

Comments:

Laboratory Ref: 1513254 Type of sample: Drinking Water Sampling point: 3 Dartry Court, Rockcorry Sampled by: John Quinn Time Sampled: nt Start/End - Dates of Analysis: 01-09-15/11-09-15 Grid Ref: 264484 319208 Status of results: Final			
Parameter	Units	Limits	
F ** Temperature	°C		nm
F ** Residual Chlorine	mg/l Cl		0.1
F ** Taste			ATC
F ** Odour			nd
True Colour	Hazen		<5
Conductivity @25°C	µS/cm @ 25	< 2760	268
pH	pH	< 9.5	7.4
Ammonia	mg/l NH4	< 0.3	<0.026
** Coliform Bacteria	No/100 ml		0
** E. Coli	No/100 ml		0
** Clostridia Perfringens	No/100ml		0
Conductivity @20°C	µS/cm @ 20	< 2500	242
Aluminium	µg/l	< 200	22
Iron	µg/l	< 200	130
Manganese	µg/l	< 50	25
Lead	µg/l	< 10	<1.0

- | | |
|---|--|
| <ul style="list-style-type: none"> 1) Results highlighted and in bold exceed specified limits. 2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document. 3) All metals analysed in EPA Richview Laboratory.
All Total Nitrogens analysed in EPA Kilkenny Laboratory.
PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd. 4) nm "Not measured" 5) nd "None detected" 6) nt "No time" - Time not recorded 7) nr "Not reported" | <ul style="list-style-type: none"> 8) tntc "Too numerous to count" 9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported. 10) F "Field measured parameters" 11) *** indicates paramters/results produced from non-accredited analytical methods. 12) Test Reports relate only to the samples tested and as described on report form. 13) Test Reports shall not be reproduced, except in full, without the consent of the EPA. 14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation. 15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms. 16) ATC = Acceptable To Consumers |
|---|--|

Signed: Ray Smith

Date: 28/Sep/2015

Ray Smith
Regional Manager,
EPA
Monaghan