

Customer

Pascal Rooney
Irish Water
Water Service
Monaghan County Council
Monaghan
Monaghan

Certificate Of Analysis

Job Number: 16-18070
Issue Number: 2
Report Date: 20 June 2016

Reason for re-issuing report: Report Amended

Site: Monaghan PWS
PO Number: 51125947
Date Samples Received: 13/06/2016

Please find attached the results for the samples received at our laboratory on 13/06/2016.

Should you have any queries regarding the report or require any further services, we would be happy to discuss your requirements. For additional information about the company please log-on to our website at the above address.

Thank you for choosing City Analysts Limited. We look forward to assisting you again.

Authorised By:



Caitlin Quinn
Deputy Quality Manager

Authorised Date: 20 June 2016

Notes:

Results relate only to the items tested.
Information on methods of analysis and performance characteristics is available on request.
Any opinions or interpretations indicated are outside the scope of our INAB accreditation.
This test report shall not be reproduced except in full or with written approval of City Analysts Limited.

Certificate Of Analysis

Customer

Pascal Rooney
Irish Water
Water Service
Monaghan County Council
Monaghan
Monaghan

Report Reference: 16-18070

Report Version: 2

Site: Monaghan PWS

Sample Description: 267525-303946 Mary McQuillan 11

Date of Sampling: 13/06/2016

Sample Type: Treated

Date Sample Received: 13/06/2016

Lab Reference Number: 321764

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
D/D3001#	15/06/2016	Aluminium, Total	5.35	ug/l	<= 200.00
D/D3000#	15/06/2016	Ammonia as NH4	0.018	mg/l	<= 0.300
D/D3006	13/06/2016	Chlorine, Free	< 0.010	mg/l	-
D/D3010#	15/06/2016	Colour True	< 5.00	Hazen	NAC & ATC
D/D3011#	13/06/2016	Conductivity @ 20 °C	391.0	uS/cm @20 °C	<= 2500.0
D/D3001#	15/06/2016	Iron	25.77	ug/l	<= 200.00
D/D3001#	15/06/2016	Lead	2.64	ug/l	<= 10.00
D/D3001#	15/06/2016	Manganese	8.30	ug/l	<= 50.00
D/	15/06/2016	Odour	0	N/A	-
D/	15/06/2016	Taste (Nature)	0	N/A	-
D/D1041#	13/06/2016	PH	7.27	pH Unit	6.50 - 9.50
D/D3054#	14/06/2016	Turbidity	0.41	NTU	NAC & ATC
D/D1214#	13/06/2016	Clostridium perfringens	< 1	cfu/100ml	<= 0
D/D1201#	13/06/2016	Coliforms	< 1.0	MPN/100ml	<= 0.0
D/D1201#	13/06/2016	E.coli	< 1.0	MPN/100ml	<= 0.0

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon