

Test Report

Report of: Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

Report to: Monaghan County Council

Report date: 16/07/14

Location sampled: Newbliss P.W.S

Date collected: 10/06/2014

Date received: 10/06/2014

Analysis group: CHECK

Comments:

Laboratory Ref:	1411416
Type of sample:	Drinking Water
Sampling point:	Co Co Offices
Sampled by:	John Quinn
Time Sampled:	nt
Start/End - Dates of Analysis:	11-06-14/24-06-14
Grid Ref:	256285 323409
Status of results:	Final

Parameter	Units	Limits	
F ** Taste			ATC
F ** Odour			nd
F ** Residual Chlorine	mg/l Cl		0.06
B12 True Colour	Hazen		<5
W0 R Conductivity @25°C	µS/cm @ 25	< 2760	367
W0 Q pH	pH	> 6.5 And < 9.5	7.8
W0 Z Ammonia	mg/l NH4	< 0.3	..007
B14 Turbidity	NTU		<0.5
** Aluminium	µg/l	< 200	<10.0
** Iron	µg/l	< 200	36
** Manganese	µg/l	< 50	<5.0
** Lead	µg/l	< 25	<1.0
** Coliform Bacteria	No/100 ml	0	0
** E. Coli	No/100 ml	0	0
** Clostridia Perfringens	No/100ml	0	0
W0 R Conductivity @20°C	µS/cm @ 20	< 2500	332

- | | |
|---|--|
| <ul style="list-style-type: none"> 1) Results highlighted and in bold exceed specified limits. 2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document. 3) All metals analysed in EPA Richview Laboratory.
All Total Nitrogens analysed in EPA Kilkenny Laboratory.
PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd. 4) nm "Not measured" 5) nd "None detected" 6) nt "No time" - Time not recorded 7) nr "Not reported" | <ul style="list-style-type: none"> 8) tntc "Too numerous to count" 9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported. 10) F "Field measured parameters" 11) *** indicates paramters/results produced from non-accredited analytical methods. 12) Test Reports relate only to the samples tested and as described on report form. 13) Test Reports shall not be reproduced, except in full, without the consent of the EPA. 14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation. 15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms. 16) ATC = Acceptable To Consumers |
|---|--|

Signed: PP Regina M.S. Ginn

Date: 16/Jul/2014

Ray Smith
Regional Manager,
EPA
Monaghan