

Customer

Pascal Rooney
Monaghan County Council
Water Services
Monaghan

Certificate Of Analysis

Job Number: 16-23021

Issue Number: 1

Report Date: 22 November 2016

Site: Oram GWS

PO Number: Not Supplied

Date Samples Received: 10/11/2016

Please find attached the results for the samples received at our laboratory on 10/11/2016.

Should you have any queries regarding the report or require any further services, we would be happy to discuss your requirements. For additional information about the company please log-on to our website at the above address.

Thank you for choosing City Analysts Limited. We look forward to assisting you again.

Authorised By:



Caitlin Quinn
Deputy Quality Manager

Authorised Date: 22 November 2016

Notes:

Results relate only to the items tested.

Information on methods of analysis and performance characteristics is available on request.

Any opinions or interpretations indicated are outside the scope of our INAB accreditation.

This test report shall not be reproduced except in full or with written approval of City Analysts Limited.

Certificate Of Analysis

Customer

Pascal Rooney
Monaghan County Council
Water Services
Monaghan

Report Reference: 16-23021

Report Version: 1

Site: Oram GWS

Sample Description: Oram GWS 6 Cois Cill, Oram

Date of Sampling: 10/11/2016

Sample Type: Treated

Date Sample Received: 10/11/2016

Lab Reference Number: 339031

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
D/D3001#	15/11/2016	Aluminium, Total	< 5.00	ug/l	<= 200.00
D/D3000#	11/11/2016	Ammonia as NH4	< 0.013	mg/l	<= 0.300
D/D3010#	15/11/2016	Colour Apparent	< 5.00	Hazen	-
D/D3011#	10/11/2016	Conductivity @ 20 °C	292.8	uS/cm @20 °C	<= 2500.0
D/D3001#	15/11/2016	Iron	8.75	ug/l	<= 200.00
D/D3001#	15/11/2016	Manganese	< 0.70	ug/l	<= 50.00
D/	11/11/2016	Odour	0	N/A	-
D/	11/11/2016	Taste (Nature)	0	N/A	-
D/D1041#	10/11/2016	PH	7.25	pH Unit	6.50 - 9.50
D/D3054#	15/11/2016	Turbidity	0.78	NTU	NAC & ATC
D/D1214#	10/11/2016	Clostridium perfringens	< 1	cfu/100ml	<= 0
D/D1201#	10/11/2016	Coliforms	< 1.0	MPN/100ml	<= 0.0
D/D1201#	10/11/2016	E.coli	< 1.0	MPN/100ml	<= 0.0

Comments

E285390 N322979

Chlorine Free: 0.22

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon