

## Test Report

**Report of:** Drinking Water [European Communities (Drinking Water)(No.2) Regulations 2007 (S.I. No.278 of 2007)].

**Report to:** Monaghan County Council

**Report date:** 20/12/13

**Location sampled:** Truagh G.W.S

Date collected: 20/11/2013

Date received: 20/11/2013

Analysis group: CHECK

Comments:

			<b>Laboratory Ref:</b>	1304624
			<b>Type of sample:</b>	Drinking Water
			<b>Sampling point:</b>	Treanor, Davagh Etra
			<b>Sampled by:</b>	John Quinn
			<b>Time Sampled:</b>	nt
			<b>Start/End - Dates of Analysis:</b>	21-11-13/27-11-13
			<b>Grid Ref:</b>	265475 344124
			<b>Status of results:</b>	<b>Final</b>
Parameter	Units	Limits		
F **	Taste			ATC
F **	Odour			nd
F **	Residual Chlorine	mg/l Cl		0.12
B12	True Colour	Hazen		10
W0 R	Conductivity @25°C	µS/cm @ 25	< 2760	183
W0 Q	pH	pH	> 6.5 And < 9.5	7.5
W0 Z	Ammonia	mg/l NH4	< 0.3	<0
B14	Turbidity	NTU		<0.5
**	Aluminium	µg/l	< 200	<10
**	Iron	µg/l	< 200	49.5
**	Manganese	µg/l	< 50	10.9
**	Lead	µg/l	< 25	<1
**	Coliform Bacteria	No/100 ml	0	0
**	E. Coli	No/100 ml	0	0
**	Clostridia Perfringens	No/100ml	0	0
W0 R	Conductivity @20°C	µS/cm @ 20	< 2500	166

- |  |  |
|--|--|
| 1) Results highlighted and in bold exceed specified limits.  | 8) tntc "Too numerous to count"  |
| 2) Uncertainty of measurement values have been assigned for each parameter and those for accredited tests are provided in a separate document.   | 9) fqc Indicates that the testing did not meet the quality control criteria as required by INAB and therefore the result cannot be reported. |
| 3) All metals analysed in EPA Richview Laboratory PAH's, Bromates, Phenols, Pesticides, Atrazine, Simazine and Surfactants are sub-contracted to either Alcontrol Laboratories or TMS Environment Ltd. | 10) F "Field measured parameters"  |
| 4) measured"   | 11) "*" indicates paramters/results produced from non-accredited analytical methods.   |
| 5) nd "None detected"  | 12) Test Reports relate only to the samples tested and as described on report form.  |
| 6) nt "No time" - Time not recorded  | 13) Test Reports shall not be reproduced, except in full, without the consent of the EPA.  |
| 7) "Not reported"  | 14) The laboratory is accredited by the INAB only for the parameters listed in the scope of Accreditation.                                   |
|  | 15) Coliform Bacteria = Total Coliforms; E.Coli = Faecal Coliforms.  |
|  | 16) ATC = Acceptable To Consumers  |

Signed: Ray Smith

Date: 20/Dec/2013

Ray Smith  
Regional Manager,  
EPA  
Monaghan