

TEST REPORT

Date Samples Received:	06/02/2019	Date of Issue:	26/02/2019
Date Analysis Commenced:	06/02/2019	Test Report Ref:	2190427
Date Analysis Completed:	26/02/2019	Customer O/No:	

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
3 CHURCH VIEW BROOMFIELD			06/02/2019 11:00	21901827	
DONAGHMOYNE GWS 285206 312793					
# Aluminium (µg Al/l)	10	200	TM58		
# Apparent colour (mg/L Pt/Co)	<2	n/a	TM62		
# Conductivity (µS/cm) at 20°C	190	2500	TM51		
# E.coli (confirmed) (cfu/100ml)	0	0	TM18		
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.91	n/a			
# Hydrogen Ion (pH)	7.1	6.5 - 9.5	TM51		
# Iron (µgFe/l)	<10	200	TM58		
# Odour (Dilution nr./Descriptor)	0	n/a	TM53		
# Taste (Dilution nr./Descriptor)	0	n/a	TM53		
* Temperature (°C)	6	n/a			
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	1.28	n/a			
# Total Coliform (cfu/100ml)	0	0	TM18		
# Turbidity (NTU)	0.088	n/a	TM52		
# TVC @ 22°C (cfu/ml)	0	n/a	TM20		

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
--------------------	--------	------------------	--------	-------------	---------

Mark Collins

MARK COLLINS (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above

Condition of all samples on receipt was satisfactory, unless otherwise indicated.

This test report should not be reproduced except in full, without written approval of the laboratory.

* Denotes results not covered by the scope of accreditation for Biosearch

Denotes results are covered by the scope of accreditation for Biosearch

Test Report Ref: 2190-427

Page 2 of 2