

Pascal Rooney Monaghan County Council Water Services M-TEC 2 Armagh Road Monaghan

TEST REPORT

Date Samples Received:06/02/2019Date of Issue:26/02/2019Date Analysis Commenced:06/02/2019Test Report Ref:2190424

Date Analysis Completed: 26/02/2019 Customer O/No:

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
2 COIS CARRIG DOOHAMLET DOOHAMLET GWS 276912 320692			06/02/	2019 10:00	21901825
# Aluminium (µg Al/l)	<8	200	TM58		
# Apparent colour (mg/L Pt/Co)	5.1	n/a	TM62		
# Conductivity (µS/cm) at 20°C	300	2500	TM51		
# E.coli (confirmed) (cfu/100ml)	0	0	TM18		
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	1.14	n/a			
# Hydrogen Ion (pH)	7.3	6.5 - 9.5	TM51		
# Iron (μgFe/l)	200	200	TM58		
# Odour (Dilution nr./Descriptor)	1	n/a	TM53		Earthy
# Taste (Dilution nr./Descriptor)		n/a	TM53	•	ont carried out due to gical failure.
* Temperature (°C)	7.5	n/a			
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	1.24	n/a			
# Total Coliform (cfu/100ml)	33	0	TM18		
# Turbidity (NTU)	0.26	n/a	TM52		
# TVC @ 22°C (cfu/ml)	8	n/a	TM20		







SAMPLE DESCRIPTION **RESULT PARAMETRIC METHOD SAMPLE** LAB REF **VALUE** DATE

Mal Clhs

MARK COLLINS (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above Condition of all samples on receipt was satisfactory, unless otherwise indicated.

This test report should not be reproduced except in full, without written approval of the laboratory.

* Denotes results not covered by the scope of accreditation for Biosearch

Denotes results are covered by the scope of accreditation for Biosearch

Page 2 of 2 Test Report Ref: 2190-424

