

Pascal Rooney Monaghan County Council Water Services M-TEC 2 Armagh Road Monaghan

## **TEST REPORT**

Date Samples Received:01/05/2019Date of Issue:14/05/2019Date Analysis Commenced:02/05/2019Test Report Ref:5190200

Date Analysis Completed: 07/05/2019 Customer O/No:

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
DUFFY, DERRYOLAM CORDUFF GWS 282820 304382			01/05/	2019 12:55	51900830
# Aluminium (µg Al/l)	<8	200	TM58		
# Apparent colour (mg/L Pt/Co)	<2	n/a	TM62		
# Conductivity (µS/cm) at 20°C	230	2500	TM51		
# E.coli (confirmed) (cfu/100ml)	0	0	TM18		
<ul> <li>Free - Residual Disinfectant (mg Cl/l) (Subcontracted)</li> </ul>	0.2	n/a			
# Hydrogen Ion (pH)	7.3	6.5 - 9.5	TM51		
# Iron (μgFe/l)	<10	200	TM58		
# Odour (Dilution nr./Descriptor)	0	n/a	TM53		
# Taste (Dilution nr./Descriptor)	0	n/a	TM53		
* Temperature (°C)	11	n/a			
<ul> <li>* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)</li> </ul>	0.39	n/a			
# Total Coliform (cfu/100ml)	0	0	TM18		
# Turbidity (NTU)	0.098	n/a	TM52		
# TVC @ 22°C (cfu/ml)	1	n/a	TM20		



SAMPLE DESCRIPTION **RESULT PARAMETRIC METHOD SAMPLE** LAB REF VALUE DATE

Mal Clhs

## MARK COLLINS (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above Condition of all samples on receipt was satisfactory, unless otherwise indicated.

This test report should not be reproduced except in full, without written approval of the laboratory.

\* Denotes results not covered by the scope of accreditation for Biosearch

# Denotes results are covered by the scope of accreditation for Biosearch

Samples tested 02.05.19 as agreed with customer.

Page 2 of 2 Test Report Ref: 5190-200

