

TEST REPORT

Date Samples Received: 01/05/2019
 Date Analysis Commenced: 02/05/2019
 Date Analysis Completed: 07/05/2019

Date of Issue: 14/05/2019
 Test Report Ref: 5190195
 Customer O/No:

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
38 COIS LOCHA, DOOHAMLET DOOHAMLET GWS 276720 320763				01/05/2019 10:45	51900825
# Aluminium ($\mu\text{g Al/l}$)	<8	200	TM58		
# Apparent colour (mg/L Pt/Co)	<2	n/a	TM62		
# Conductivity ($\mu\text{S/cm}$) at 20°C	270	2500	TM51		
# E.coli (confirmed) (cfu/100ml)	0	0	TM18		
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.19	n/a			
# Hydrogen Ion (pH)	7.3	6.5 - 9.5	TM51		
# Iron ($\mu\text{gFe/l}$)	<10	200	TM58		
# Odour (Dilution nr./Descriptor)	0	n/a	TM53		
# Taste (Dilution nr./Descriptor)	0	n/a	TM53		
* Temperature (°C)	12.5	n/a			
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.45	n/a			
# Total Coliform (cfu/100ml)	0	0	TM18		
# Turbidity (NTU)	0.1	n/a	TM52		
# TVC @ 22°C (cfu/ml)	6	n/a	TM20		

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
--------------------	--------	------------------	--------	-------------	---------

Mark Collins

MARK COLLINS (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above
 Condition of all samples on receipt was satisfactory, unless otherwise indicated.
 This test report should not be reproduced except in full, without written approval of the laboratory.
 * Denotes results not covered by the scope of accreditation for Biosearch
 # Denotes results are covered by the scope of accreditation for Biosearch
 Samples tested 02.05.19 as agreed with customer.

