

Pascal Rooney Monaghan County Council Water Services M-TEC 2 Armagh Road Monaghan

TEST REPORT

Date Samples Received:03/04/2019Date Analysis Commenced:04/04/2019Date Analysis Completed:09/04/2019					9/04/2019 4190388	
SAMPLE DESCRIPTION		RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
WHYTE, TULLYNASKEAGH WE GWS 284616 301856	EST KILANNY			03/04/	2019 12:15	41901667
# Aluminium (µg Al/l)		<8	200	TM58		
# Apparent colour (mg/L Pt/Co)		<2	n/a	TM62		
# Conductivity (µS/cm) at 20°C		500	2500	TM51		
# E.coli (confirmed) (cfu/100ml)		0	0	TM18		
 * Free - Residual Disinfectant (mg Cl/l) (Subcontracted) 		0.41	n/a			
# Hydrogen Ion (pH)		7.5	6.5 - 9.5	TM51		
[#] Iron (μgFe/l)		<10	200	TM58		
# Odour (Dilution nr./Descriptor)		0	n/a	TM53		
# Taste (Dilution nr./Descriptor)		0	n/a	TM53		
* Temperature (°C)		9.5	n/a			
 * Total - Residual Disinfectant (mg Cl/l) (Subcontracted) 		0.75	n/a			
# Total Coliform (cfu/100ml)		0	0	TM18		
# Turbidity (NTU)		0.06	n/a	TM52		
# TVC @ 22°C (cfu/ml)		34	n/a	TM20		

Page 1 of 2





SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF

Mark Clks

MARK COLLINS (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above

Condition of all samples on receipt was satisfactory, unless otherwise indicated.

This test report should not be reproduced except in full, without written approval of the laboratory.

* Denotes results not covered by the scope of accreditation for Biosearch

Denotes results are covered by the scope of accreditation for Biosearch

Sample tested 04.04.19 as agreed with customer.

Test Report Ref: 4190-388

Page 2 of 2

