

## TEST REPORT

Date Samples Received: 07/08/2019  
 Date Analysis Commenced: 07/08/2019  
 Date Analysis Completed: 13/08/2019

Date of Issue: 14/08/2019  
 Test Report Ref: 8190480  
 Customer O/No:

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
<b>MCKEOWN, BEAGH CORDUFF GWS 281189 305827</b>				07/08/2019 12:35	81902559
Aluminium ( $\mu\text{g Al/l}$ )	<8	200	TM58		
Apparent colour (mg/L Pt/Co)	<1	n/a	TM62		
Conductivity ( $\mu\text{S/cm}$ ) at 20°C	220	2500	TM51		
E.coli (confirmed) (cfu/100ml)	0	0	TM18		
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.27	n/a			
Hydrogen Ion (pH)	7.3	6.5 - 9.5	TM51		
Iron ( $\mu\text{gFe/l}$ )	25	200	TM58		
Odour (Dilution nr./Descriptor)	0	n/a	TM53		
Taste (Dilution nr./Descriptor)	0	n/a	TM53		
* Temperature (°C)	17	n/a			
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.4	n/a			
Total Coliform (cfu/100ml)	0	0	TM18		
Turbidity (NTU)	0.12	n/a	TM52		
TVC @ 22°C (cfu/ml)	8	n/a	TM20		

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
--------------------	--------	------------------	--------	-------------	---------

*L2100*

**LOUISE ELDER (TECHNICAL MANAGER)**

Results of analysis relate only to samples as received and tested on the date(s) detailed above  
 Condition of all samples on receipt was satisfactory, unless otherwise indicated.  
 This test report should not be reproduced except in full, without written approval of the laboratory.  
 \* Denotes results not covered by the scope of accreditation for Biosearch

