

TEST REPORT

Date Samples Received: 07/08/2019
 Date Analysis Commenced: 07/08/2019
 Date Analysis Completed: 13/08/2019

Date of Issue: 14/08/2019
 Test Report Ref: 8190477
 Customer O/No:

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
MCHUGH TULLYVARAGH DONAGHMOYNE GWS 284485 308922				07/08/2019 10:55	81902556
Aluminium ($\mu\text{g Al/l}$)	66	200	TM58		
Apparent colour (mg/L Pt/Co)	3.6	n/a	TM62		
Conductivity ($\mu\text{S/cm}$) at 20°C	180	2500	TM51		
E.coli (confirmed) (cfu/100ml)	0	0	TM18		
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.08	n/a			
Hydrogen Ion (pH)	7.6	6.5 - 9.5	TM51		
Iron ($\mu\text{gFe/l}$)	<10	200	TM58		
Manganese ($\mu\text{gMn/l}$)	14	50	TM58		
Odour (Dilution nr./Descriptor)	0	n/a	TM53		
Taste (Dilution nr./Descriptor)	0	n/a	TM53		
* Temperature (°C)	17	n/a			
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.38	n/a			
Total Coliform (cfu/100ml)	0	0	TM18		
Turbidity (NTU)	0.11	n/a	TM52		
TVC @ 22°C (cfu/ml)	1	n/a	TM20		

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
--------------------	--------	------------------	--------	-------------	---------

L2100

LOUISE ELDER (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above
 Condition of all samples on receipt was satisfactory, unless otherwise indicated.
 This test report should not be reproduced except in full, without written approval of the laboratory.
 * Denotes results not covered by the scope of accreditation for Biosearch

