

TEST REPORT

Date Samples Received: 02/10/2019
 Date Analysis Commenced: 02/10/2019
 Date Analysis Completed: 15/11/2019

Date of Issue: 20/11/2019
 Test Report Ref: 10190281
 Customer O/No: MCKENNA, DRUMINTIN

MCKENNA, DRUMINTIN

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
MCKENNA DRUMINTIN DRUMGOLE GWS 261363 318835				02/10/2019 12:45	101901210
* 1,2 dichloroethane (µg/l) (Subcontracted)	<0.079	n/a			
* 2,4-D (µg/L) (Subcontracted)	0.014	0.1			
Aluminium (µg Al/l)	81	200	TM58		
Antimony (µgSb/l)	<0.1	5	TM64		
Arsenic (µg As/l)	0.26	10	TM64		
* Atrazine (µg/L) (Subcontracted)	<0.005	0.1			
* Bentazone (µg/L) (Subcontracted)	<0.005	0.1			
* Benzene (µg/l) (Subcontracted)	<0.041	n/a			
* Benzo(a)pyrene (µg/l) (Subcontracted)	<0.01	0.01			
* Benzo(b)fluoranthene (µg/l) (Subcontracted)	<0.01	n/a			
* Benzo(ghi)perylene (µg/l) (Subcontracted)	<0.01	n/a			
* Benzo(k)fluoranthene (µg/l) (Subcontracted)	<0.01	n/a			
* Boron (mg B/l) (Subcontracted)	0.03	1			
* Bromate (µg BrO3/l) (Subcontracted)	<0.1	n/a			
Bromodichloromethane (µg/l)	21	n/a	TM55		
Bromoform (µg/l)	<2	n/a	TM55		
Cadmium (µg Cd/l)	<0.1	5	TM64		
* Chlorfenvinphos (µg/L) (Subcontracted)	<0.005	0.1			

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
Chloride (mgCl/l)	30	250	TM57		
Chloroform (µg/l)	78.6	n/a	TM55		
Chromium (µg Cr/l)	<0.5	50	TM64		
Cl. perfringens (cfu/100ml)	0	0	TM36		
* Clopyralid (µg/L) (Subcontracted)	<0.005	0.1			
Copper (mg Cu/l)	0.011	2	TM64		
* Cyanide (µg Cn/l) (Subcontracted)	<1.2	50			
* Cypermethrin (µg/L) (Subcontracted)	<0.003	0.1			
Dibromochloromethane (µg/l)	3.2	n/a	TM55		
* Dichlobenil (µg/L) (Subcontracted)	<0.003	0			
* Dichlorprop (µg/L) (Subcontracted)	<0.005	0.1			
* Diflufenican (µg/L) (Subcontracted)	<0.005	0.1			
* Diuron (µg/L) (Subcontracted)	<0.005	0.1			
Enterococci (cfu/100ml)	0	0	TM19		
Fluoride (mg F/l)	<0.1	0.8	TM57		
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.04	n/a			
* Glyphosate (µg/L) (Subcontracted)	<0.005	0.1			
Hydrogen Ion (pH)	7.4	6.5 - 9.5	TM51		
* Indeno(1,2,3-cd)pyrene (µg/l) (Subcontracted)	<0.005	n/a			
Iron (µgFe/l)	<10	200	TM58		
* Isoproturon (µg/L) (Subcontracted)	<0.005	0.1			
Lead (µgPb/L)	0.23	10	TM82		
* Linuron (µg/L) (Subcontracted)	<0.005	0.1			
Manganese (µgMn/l)	<2	50	TM58		
* MCPA (µg/L) (Subcontracted)	<0.005	0.1			
* MCPP(Mecoprop) (µg/L) (Subcontracted)	<0.005	0.1			
* Mercury (µg Hg/l) (Subcontracted)	0.03	1			
* Metaldehyde (Subcontracted)	<0.005	0.1			

Test Report Ref: 10190281

Page 2 of 4

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
Nickel (µg Ni/l)	0.52	20	TM64		
Nitrate (mg NO3/l)	<1	50	TM57		
Nitrite (mg NO2/l)	<0.007	0.5	TM57		
Odour (Dilution nr./Descriptor)	0	n/a	TM53		
* Pendimethalin (µg/L) (Subcontracted)	<0.003	0.1			
* Pesticides: Total (µg/l) (Subcontracted)	0.03	0.5			
* Polycyclic Aromatic Hydrocarbons (µg/l) (Subcon)	<0.01	0.1			
* Propyzamide (µg/L) (Subcontracted)	<0.005	0.1			
Selenium (µg Se/l)	0.42	10	TM64		
* Simazine (µg/L) (Subcontracted)	<0.005	0.1			
* Sodium (mgNa/l) (Subcontracted)	16.5	200			
Sulphate (mgSO4/l)	6	250	TM57		
Taste (Dilution nr./Descriptor)	0	n/a	TM53		
* Temperature (°C)	14	n/a			
* Tetrachloroethene (µg/l) (Subcontracted)	<0.39	n/a			
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.22	n/a			
Total Coliform (cfu/100ml)	0	0	TM18		
Total Organic Carbon (mgC/l)	4.2	n/a	TM98		
Total Trihalomethanes (µg/l)	<100	100	TM55		
* Trichloroethene (µg/l) (Subcontracted)	<0.4	n/a			
* Triclopyr (µg/L) (Subcontracted)	0.008	0.1			

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
--------------------	--------	------------------	--------	-------------	---------

L-2100

LOUISE ELDER (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above
 Condition of all samples on receipt was satisfactory, unless otherwise indicated.
 This test report should not be reproduced except in full, without written approval of the laboratory.
 * Denotes results not covered by the scope of accreditation for Biosearch
 Solvents analysis out of stability, results indicative only
 Only 1 x unfixd vial supplied for analysis. (SOLV suite)

