

TEST REPORT

Date Samples Received:	04/12/2019	Date of Issue:	10/12/2019
Date Analysis Commenced:	04/12/2019	Test Report Ref:	12190379
Date Analysis Completed:	10/12/2019	Customer O/No:	

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
DONAGHAMOYNE GWS 285197 312793 3 CHURCH VIEW BROOMFIELDS				04/12/2019 12:15	121902106
Aluminium ($\mu\text{g Al/l}$)	13	200	TM58		
Apparent colour (mg/L Pt/Co)	7.8	n/a	TM62		
Conductivity ($\mu\text{S/cm}$) at 20°C	180	2500	TM51		
E.coli (confirmed) (cfu/100ml)	0	0	TM18		
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.76	n/a			
Hydrogen Ion (pH)	7.2	6.5 - 9.5	TM51		
Iron ($\mu\text{gFe/l}$)	<10	200	TM58		
Manganese ($\mu\text{gMn/l}$)	61	50	TM58		
Odour (Dilution nr./Descriptor)	0	n/a	TM53		
Taste (Dilution nr./Descriptor)	0	n/a	TM53		
* Temperature (°C)	7.1	n/a			
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	1.02	n/a			
Total Coliform (cfu/100ml)	0	0	TM18		
Turbidity (NTU)	0.51	n/a	TM52		
TVC @ 22°C (cfu/ml)	0	n/a	TM20		

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
--------------------	--------	------------------	--------	-------------	---------

L2100

LOUISE ELDER (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above
 Condition of all samples on receipt was satisfactory, unless otherwise indicated.
 This test report should not be reproduced except in full, without written approval of the laboratory.
 * Denotes results not covered by the scope of accreditation for Biosearch

