

Pascal Rooney Monaghan County Council Water Services M-TEC 2 Armagh Road Monaghan

TEST REPORT

Date Samples Received: 13/11/2019 Date of Issue: 09/12/2019
Date Analysis Commenced: 14/11/2019 Test Report Ref: 11191249

Date Analysis Completed: 22/11/2019 Customer O/No:

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE DATE	LAB REF
DONAGHAMOYNE GWS 283227 317879 CONLON,DRUMCREW			13/11/2019 11:05 111905736		1905736
Aluminium (μg Al/l)	9.5	200	TM58		
Apparent colour (mg/L Pt/Co)	4	n/a	TM62		
Conductivity (µS/cm) at 20°C	190	2500	TM51		
E.coli (confirmed) (cfu/100ml)	0	0	TM18		
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.15	n/a			
Hydrogen Ion (pH)	7.2	6.5 - 9.5	TM51		
Iron (μgFe/l)	<10	200	TM58		
* Odour (Dilution number) (Subcontracted)	3	n/a			Plastic
* Taste (Dilution number) (Subcontracted)	0	n/a			
* Temperature (°C)	12.8	n/a			
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.38	n/a			
Total Coliform (cfu/100ml)	0	0	TM18		
Turbidity (NTU)	0.14	n/a	TM52		
TVC @ 22°C (cfu/ml)	39	n/a	TM20		



SAMPLE DESCRIPTION RESULT PARAMETRIC METHOD SAMPLE LAB REF VALUE DATE

D. Outhre

DEBY ARTHUR (QUALITY MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above Condition of all samples on receipt was satisfactory, unless otherwise indicated.

This test report should not be reproduced except in full, without written approval of the laboratory.

* Denotes results not covered by the scope of accreditation for Biosearch

Taste & Odour not tested in recommended bottle. Results may be invalid.

Test Report Ref: 11191249 Page 2 of 2

