

Pascal Rooney Monaghan County Council Water Services M-TEC 2 Armagh Road Monaghan

TEST REPORT

Date Samples Received: 13/11/2019 Date of Issue: 04/12/2019
Date Analysis Commenced: 14/11/2019 Test Report Ref: 11191247

Date Analysis Completed: 03/12/2019 Customer O/No:

SAMPLE DESCRIPTION	RESULT	PARAMETRIC VALUE	METHOD	SAMPLE LAB REF DATE
DOOHAMLET GWS 276680 320541 BOYLAN , DOOHAMLET			13/11/2019 10:00 111905734	
Aluminium (μg Al/l)	<8	200	TM58	
Apparent colour (mg/L Pt/Co)	3.3	n/a	TM62	
Conductivity (µS/cm) at 20°C	280	2500	TM51	
E.coli (confirmed) (cfu/100ml)	0	0	TM18	
* Free - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.59	n/a		
Hydrogen Ion (pH)	7	6.5 - 9.5	TM51	
Iron (μgFe/l)	160	200	TM58	
* Odour (Dilution number) (Subcontracted)	0	n/a		
* Taste (Dilution number) (Subcontracted)	0	n/a		
* Temperature (°C)	9.5	n/a		
* Total - Residual Disinfectant (mg Cl/l) (Subcontracted)	0.91	n/a		
Total Coliform (cfu/100ml)	0	0	TM18	
Turbidity (NTU)	0.2	n/a	TM52	
TVC @ 22°C (cfu/ml)	0	n/a	TM20	



SAMPLE DESCRIPTION RESULT PARAMETRIC METHOD SAMPLE LAB REF VALUE DATE

2200r

LOUISE ELDER (TECHNICAL MANAGER)

Results of analysis relate only to samples as received and tested on the date(s) detailed above Condition of all samples on receipt was satisfactory, unless otherwise indicated. This test report should not be reproduced except in full, without written approval of the laboratory.

* Denotes results not covered by the scope of accreditation for Biosearch

Taste & Odour not tested in recommended bottle. Results may be invalid.

Test Report Ref: 11191247 Page 2 of 2

