

**Customer**

Pascal Rooney  
Monaghan County Council  
Water Services  
Monaghan

**Certificate Of Analysis**

**Job Number:** 20-70563

**Issue Number:** 2

**Report Date:** 3 February 2020

Reason for re-issuing report: Amended report to correct site details.

**Site:** Kilanny GWS (Audit)

**PO Number:** Not Supplied

**Date Samples Received:** 15/01/2020

Please find attached the results for the samples received at our laboratory on 15/01/2020.

Should you have any queries regarding the report or require any further services, we would be happy to discuss your requirements. For additional information about the company please log-on to our website at the above address.

Thank you for choosing City Analysts Limited. We look forward to assisting you again.

**Authorised By:**



Shane Reynolds  
Laboratory Manager

**Authorised Date:** 3 February 2020

**Notes are not INAB accredited**

Results relate only to the items tested.

Information on methods of analysis and uncertainty of measurement is available on request.

Any opinions or interpretations indicated are outside the scope of our INAB accreditation.

This test report shall not be reproduced except in full or with written approval of City Analysts Limited.

## Certificate Of Analysis

### Customer

Pascal Rooney  
Monaghan County Council  
Water Services  
Monaghan

**Report Reference:** 20-70563

**Report Version:** 2

**Site:** Kilanny GWS (Audit)

**Sample Description:** Ruth , Annacroff (E287093-N303250)

**Date of Sampling:** 15/01/2020

**Sample Type:** Treated

**Date Sample Received:** 15/01/2020

**Lab Reference Number:** 487650

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
#*U	-	1,2-Dichloroethane	< 0.10	ug/l	-
D/D3000#	17/01/2020	Ammonia as NH4	< 0.013	mg/l	<= 0.300
#*	-	Benzene	< 0.10	ug/l	-
D/D3001#	17/01/2020	Boron	< 50.00	ug/l	<= 1000.00
D/D3001#	16/01/2020	Cadmium	< 0.2	ug/l	<= 5.0
	15/01/2020	Chlorine, Free Onsite	1.050	mg/l	-
	15/01/2020	Chlorine, Total Onsite	1.320	mg/l	-
D/D3000#	17/01/2020	Chloride	47.458	mg/l	<= 250.000
D/D3001#	16/01/2020	Chromium	< 0.9	ug/l	<= 50.0
D/D3001#	16/01/2020	Copper	18.0	ug/l	<= 2000.0
D/D3015#	16/01/2020	Fluoride	< 0.1	mg/l	<= 0.8
D/D3001#	16/01/2020	Lead	< 1.7	ug/l	<= 10.0
D/D3001#	16/01/2020	Manganese	< 0.7	ug/l	<= 50.0
D/D3000#	17/01/2020	Nitrite as N02	< 0.066	mg/l	<= 0.500
D/D3000#	17/01/2020	Nitrate as N03	14.094	mg/l	<= 50.000
D/D3001#	16/01/2020	Nickel	3.4	ug/l	<= 20.0
EW188#*	-	Antimony - Total	0.5	ug/L	-
EW188#*	-	Arsenic - Total	< 0.2	ug/L	<= 10.0

# = INAB Accredited, U = UKAS Accredited, \* = Subcontracted

**Note:**

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

## Certificate Of Analysis

### Customer

Pascal Rooney  
Monaghan County Council  
Water Services  
Monaghan

**Report Reference:** 20-70563

**Report Version:** 2

**Site:** Kilanny GWS (Audit)

**Sample Description:** Ruth , Annacroff (E287093-N303250)

**Date of Sampling:** 15/01/2020

**Sample Type:** Treated

**Date Sample Received:** 15/01/2020

**Lab Reference Number:** 487650

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
EW188#*	-	Mercury - Total	< 0.02	ug/L	-
EW188#*	-	Selenium - Total	0.3	ug/L	-
EW154M-1#*	-	Cyanide-Free	1.4000	ug/L	-
EW137#*	-	Bromate	< 1.0000	ug/L	<= 10.0000
D/D1041#	16/01/2020	PH	7.42	pH Unit	6.50 - 9.50
D/D3001#	16/01/2020	Sodium	12.035	mg/l	<= 200.000
D/D3000#	17/01/2020	Sulphate	< 20.000	mg/l	<= 250.000
D/	15/01/2020	Temperature Onsite	6.0	°C	-
#*	-	Tetrachloroethene	< 0.10	ug/l	-
#*	-	Trichloroethene	< 0.10	ug/l	-
S/S3224#	21/01/2020	Total Organic Carbon	3.530	mg/l	NAC & ATC
S266*	-	Pesticides Total	< 0.01	ug/l	<= 0.50
D/D1214#	15/01/2020	Clostridium perfringens	< 1	cfu/100ml	<= 0
D/D1205#	15/01/2020	Enterococci	< 1	cfu/100ml	<= 0
QN009961 LCMSMS-Acid Herbicides					
EO162#*	-	2,4 D	< 0.0050	ug/L	<= 0.1000
EO162#*	-	2,3,6-Trichlorobenzoic Acid (TBA)	< 0.0050	ug/L	<= 0.1000
EO162#*	-	2,4-DB	< 0.0050	ug/L	-

# = INAB Accredited, U = UKAS Accredited, \* = Subcontracted

**Note:**

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

## Certificate Of Analysis

### Customer

Pascal Rooney  
Monaghan County Council  
Water Services  
Monaghan

**Report Reference:** 20-70563

**Report Version:** 2

**Site:** Kilanny GWS (Audit)

**Sample Description:** Ruth , Annacroff (E287093-N303250)

**Date of Sampling:** 15/01/2020

**Sample Type:** Treated

**Date Sample Received:** 15/01/2020

**Lab Reference Number:** 487650

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
EO162#*	-	Bentazone	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Boscalid	< 0.005	ug/L	-
EO162#*	-	Bromoxynil	< 0.0050	ug/L	-
EO162#*	-	Clopyralid	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Dicamba	< 0.0050	ug/L	-
EO162#*	-	Dichloroprop (24DP)	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Fluroxypyr	< 0.0050	ug/L	-
EO162#*	-	MCPA	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Mecoprop (MCP)	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Pentachlorophenol (PCP)	< 0.0050	ug/L	-
EO162#*	-	Picloram	< 0.0050	ug/L	-
EO162#*	-	Trichlopyr	< 0.0050	ug/L	<= 0.1000
QN009961 LCMSMS-Glyphosate & AMPA					
EO164#*	-	Glyphosate-LC	< 0.0050	ug/L	<= 0.1000
QN009961 GCMSMS-Pesticides & PAH					
EO181#*	-	Anthracene	< 0.0100	ug/L	-
EO181#*	-	Benzo (a) Pyrene	< 0.0030	ug/L	<= 0.0100
EO181#*	-	Benzo (b) Fluoranthene	< 0.0100	ug/L	-

# = INAB Accredited, U = UKAS Accredited, \* = Subcontracted

**Note:**

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

## Certificate Of Analysis

### Customer

Pascal Rooney  
Monaghan County Council  
Water Services  
Monaghan

**Report Reference:** 20-70563

**Report Version:** 2

**Site:** Kilanny GWS (Audit)

**Sample Description:** Ruth , Annacroff (E287093-N303250)

**Date of Sampling:** 15/01/2020

**Sample Type:** Treated

**Date Sample Received:** 15/01/2020

**Lab Reference Number:** 487650

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
EO181#*	-	Benzo (ghi) Perylene	< 0.0100	ug/L	-
EO181#*	-	Benzo (k) Fluoranthene	< 0.0100	ug/L	-
EO181#*	-	Cypermethrin-(IH)	< 0.0030	ug/L	<= 0.1000
EO181#*	-	Dichlobenil (IH)	< 0.0030	ug/L	<= 0.1000
EO181#*	-	Dieldrin	< 0.0050	ug/L	-
EO181#*	-	Drinking Water PAH Sum	< 0.0100	ug/L	<= 0.1000
EO181#*	-	Indeno (123-cd) Pyrene	< 0.0050	ug/L	-
EO181#*	-	Pendimethalin (IH)	< 0.0030	ug/L	-
QN009961 LCMSMS-Pesticide Suite A					
EO165#*	-	Atrazine-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Chlorfenvinphos-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Chlorotoluron-LC	< 0.0050	ug/L	-
EO165#*	-	Chlorpropham-LC	< 0.0050	ug/L	-
EO165#*	-	Diazinon-LC	< 0.0050	ug/L	-
EO165#*	-	Diflufenican-Triaz-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Diuron-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Epoxiconazole-LC	< 0.0050	ug/L	-
EO165#*	-	Isoproturon-LC	< 0.0050	ug/L	<= 0.1000

# = INAB Accredited, U = UKAS Accredited, \* = Subcontracted

**Note:**

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

## Certificate Of Analysis

### Customer

Pascal Rooney  
Monaghan County Council  
Water Services  
Monaghan

**Report Reference:** 20-70563

**Report Version:** 2

**Site:** Kilanny GWS (Audit)

**Sample Description:** Ruth , Annacroff (E287093-N303250)

**Date of Sampling:** 15/01/2020

**Sample Type:** Treated

**Date Sample Received:** 15/01/2020

**Lab Reference Number:** 487650

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
EO165#*	-	Linuron-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Metalddehyde-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Metazachlor-LC	< 0.0050	ug/L	-
EO165#*	-	Propazine-LC	< 0.0050	ug/L	-
EO165#*	-	Propyzamide-Triaz-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Simazine-LC	< 0.0050	ug/L	<= 0.1000
THM					
#*	-	Bromodichloromethane	17.00	ug/l	-
#*	-	Trichloromethane	23.00	ug/l	-
#*	-	Bromoform	< 1.00	ug/l	-
#*	-	Dibromochloromethane	8.00	ug/l	-
#*	-	Total THM	47.00	ug/l	<= 100.00

### Comments

Coordinates E287093-N303250

# = INAB Accredited, U = UKAS Accredited, \* = Subcontracted

### Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon