

Customer

Pascal Rooney
Monaghan County Council
Water Services
Monaghan

Certificate Of Analysis

Job Number: 20-70566
Issue Number: 2
Report Date: 3 February 2020

Reason for re-issuing report: Amended report to correct site details.

Site: Tydavnet GWS (Audit)
PO Number: Not Supplied
Date Samples Received: 15/01/2020

Please find attached the results for the samples received at our laboratory on 15/01/2020.

Should you have any queries regarding the report or require any further services, we would be happy to discuss your requirements. For additional information about the company please log-on to our website at the above address.

Thank you for choosing City Analysts Limited. We look forward to assisting you again.

Authorised By:



Shane Reynolds
Laboratory Manager

Authorised Date: 3 February 2020

Notes are not INAB accredited

Results relate only to the items tested.
Information on methods of analysis and uncertainty of measurement is available on request.
Any opinions or interpretations indicated are outside the scope of our INAB accreditation.
This test report shall not be reproduced except in full or with written approval of City Analysts Limited.

Certificate Of Analysis

Customer

Pascal Rooney
Monaghan County Council
Water Services
Monaghan

Report Reference: 20-70566

Report Version: 2

Site: Tydavnet GWS (Audit)

Sample Description: Mullaghinshigo Tydavnet(E281386-N300241)

Date of Sampling: 15/01/2020

Sample Type: Treated

Date Sample Received: 15/01/2020

Lab Reference Number: 487652

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
#*U	-	1,2-Dichloroethane	< 0.10	ug/l	-
D/D3000#	17/01/2020	Ammonia as NH4	< 0.013	mg/l	<= 0.300
#*	-	Benzene	< 0.10	ug/l	-
D/D3001#	17/01/2020	Boron	90.14	ug/l	<= 1000.00
D/D3001#	16/01/2020	Cadmium	< 0.2	ug/l	<= 5.0
	15/01/2020	Chlorine, Free Onsite	0.520	mg/l	-
	15/01/2020	Chlorine, Total Onsite	1.800	mg/l	-
D/D3000#	17/01/2020	Chloride	29.491	mg/l	<= 250.000
D/D3001#	16/01/2020	Chromium	< 0.9	ug/l	<= 50.0
D/D3001#	16/01/2020	Copper	< 2.0	ug/l	<= 2000.0
D/D3015#	16/01/2020	Fluoride	0.7	mg/l	<= 0.8
D/D3001#	16/01/2020	Lead	< 1.7	ug/l	<= 10.0
D/D3001#	16/01/2020	Manganese	< 0.7	ug/l	<= 50.0
D/D3000#	17/01/2020	Nitrite as N02	< 0.066	mg/l	<= 0.500
D/D3000#	17/01/2020	Nitrate as N03	< 8.900	mg/l	<= 50.000
D/D3001#	16/01/2020	Nickel	< 0.5	ug/l	<= 20.0
EW188#*	-	Antimony - Total	0.5	ug/L	-
EW188#*	-	Arsenic - Total	< 0.2	ug/L	<= 10.0

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

Certificate Of Analysis

Customer

Pascal Rooney
Monaghan County Council
Water Services
Monaghan

Report Reference: 20-70566

Report Version: 2

Site: Tydavnet GWS (Audit)

Sample Description: Mullaghinshigo Tydavnet(E281386-N300241)

Date of Sampling: 15/01/2020

Sample Type: Treated

Date Sample Received: 15/01/2020

Lab Reference Number: 487652

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
EW188#*	-	Mercury - Total	< 0.02	ug/L	-
EW188#*	-	Selenium - Total	< 0.2	ug/L	-
EW154M-1#*	-	Cyanide-Free	< 1.2000	ug/L	-
EW137#*	-	Bromate	< 1.0000	ug/L	<= 10.0000
D/D1041#	16/01/2020	PH	7.47	pH Unit	6.50 - 9.50
D/D3001#	16/01/2020	Sodium	55.061	mg/l	<= 200.000
D/D3000#	17/01/2020	Sulphate	39.414	mg/l	<= 250.000
D/	15/01/2020	Temperature Onsite	7.8	°C	-
#*	-	Tetrachloroethene	< 0.10	ug/l	-
#*	-	Trichloroethene	< 0.10	ug/l	-
S/S3224#	21/01/2020	Total Organic Carbon	1.680	mg/l	NAC & ATC
S266*	-	Pesticides Total	< 0.01	ug/l	<= 0.50
D/D1214#	15/01/2020	Clostridium perfringens	< 1	cfu/100ml	<= 0
D/D1205#	15/01/2020	Enterococci	< 1	cfu/100ml	<= 0
QN009961 LCMSMS-Acid Herbicides					
EO162#*	-	2,4 D	< 0.0050	ug/L	<= 0.1000
EO162#*	-	2,3,6-Trichlorobenzoic Acid (TBA)	< 0.0050	ug/L	<= 0.1000
EO162#*	-	2,4-DB	< 0.0050	ug/L	-

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

Certificate Of Analysis

Customer

Pascal Rooney
Monaghan County Council
Water Services
Monaghan

Report Reference: 20-70566

Report Version: 2

Site: Tydavnet GWS (Audit)

Sample Description: Mullaghinshigo Tydavnet(E281386-N300241)

Date of Sampling: 15/01/2020

Sample Type: Treated

Date Sample Received: 15/01/2020

Lab Reference Number: 487652

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
EO162#*	-	Bentazone	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Boscalid	< 0.005	ug/L	-
EO162#*	-	Bromoxynil	< 0.0050	ug/L	-
EO162#*	-	Clopyralid	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Dicamba	< 0.0050	ug/L	-
EO162#*	-	Dichloroprop (24DP)	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Fluroxypyr	< 0.0050	ug/L	-
EO162#*	-	MCPA	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Mecoprop (MCP)	< 0.0050	ug/L	<= 0.1000
EO162#*	-	Pentachlorophenol (PCP)	< 0.0050	ug/L	-
EO162#*	-	Picloram	< 0.0050	ug/L	-
EO162#*	-	Trichlopyr	< 0.0050	ug/L	<= 0.1000
QN009961 LCMSMS-Glyphosate & AMPA					
EO164#*	-	Glyphosate-LC	< 0.0050	ug/L	<= 0.1000
QN009961 GCMSMS-Pesticides & PAH					
EO181#*	-	Anthracene	< 0.0100	ug/L	-
EO181#*	-	Benzo (a) Pyrene	< 0.0030	ug/L	<= 0.0100
EO181#*	-	Benzo (b) Fluoranthene	< 0.0100	ug/L	-

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

Certificate Of Analysis

Customer

Pascal Rooney
Monaghan County Council
Water Services
Monaghan

Report Reference: 20-70566

Report Version: 2

Site: Tydavnet GWS (Audit)

Sample Description: Mullaghinshigo Tydavnet(E281386-N300241)

Date of Sampling: 15/01/2020

Sample Type: Treated

Date Sample Received: 15/01/2020

Lab Reference Number: 487652

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
EO181#*	-	Benzo (ghi) Perylene	< 0.0100	ug/L	-
EO181#*	-	Benzo (k) Fluoranthene	< 0.0100	ug/L	-
EO181#*	-	Cypermethrin-(IH)	< 0.0030	ug/L	<= 0.1000
EO181#*	-	Dichlobenil (IH)	< 0.0030	ug/L	<= 0.1000
EO181#*	-	Dieldrin	< 0.0050	ug/L	-
EO181#*	-	Drinking Water PAH Sum	< 0.0100	ug/L	<= 0.1000
EO181#*	-	Indeno (123-cd) Pyrene	< 0.0050	ug/L	-
EO181#*	-	Pendimethalin (IH)	< 0.0030	ug/L	-
QN009961 LCMSMS-Pesticide Suite A					
EO165#*	-	Atrazine-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Chlorfenvinphos-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Chlorotoluron-LC	< 0.0050	ug/L	-
EO165#*	-	Chlorpropham-LC	< 0.0050	ug/L	-
EO165#*	-	Diazinon-LC	< 0.0050	ug/L	-
EO165#*	-	Diflufenican-Triaz-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Diuron-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Epoxiconazole-LC	< 0.0050	ug/L	-
EO165#*	-	Isoproturon-LC	< 0.0050	ug/L	<= 0.1000

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon

Certificate Of Analysis

Customer

Pascal Rooney
Monaghan County Council
Water Services
Monaghan

Report Reference: 20-70566

Report Version: 2

Site: Tydavnet GWS (Audit)

Sample Description: Mullaghinshigo Tydavnet(E281386-N300241)

Date of Sampling: 15/01/2020

Sample Type: Treated

Date Sample Received: 15/01/2020

Lab Reference Number: 487652

Site / Method Ref.	Analysis Start Date	Parameter	Result	Units	PV Value (Drinking Water Only)
EO165#*	-	Linuron-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Metaldehyde-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Metazachlor-LC	< 0.0050	ug/L	-
EO165#*	-	Propazine-LC	< 0.0050	ug/L	-
EO165#*	-	Propyzamide-Triaz-LC	< 0.0050	ug/L	<= 0.1000
EO165#*	-	Simazine-LC	< 0.0050	ug/L	<= 0.1000
THM					
#*	-	Bromodichloromethane	6.00	ug/l	-
#*	-	Trichloromethane	11.00	ug/l	-
#*	-	Bromoform	< 1.00	ug/l	-
#*	-	Dibromochloromethane	4.00	ug/l	-
#*	-	Total THM	21.00	ug/l	<= 100.00

Comments

Coordinates E263284-N338795

= INAB Accredited, U = UKAS Accredited, * = Subcontracted

Note:

PV Value is the parametric value, taken from European Communities, (Drinking Water) Regulations, 2014. S.I. No. 122 of 2014 and relates only to drinking water samples.

For queries on results, please contact us within two weeks of the report date to ensure that we can accommodate your query as samples cannot be stored indefinitely.

NAC & ATC - No abnormal change and acceptable to customers.

TVC - Total viable count

Site D = Analysed at City Analysts Dublin. Site S = Analysed at City Analysts Shannon