

A copy of this certificate is available on www.fitzsci.ie

Customer supplied information appear in italics.

<b>Customer</b>	<i>Dermot McCague Monaghan Co. Co. GWS Glen Road  Monaghan,H18 YT50</i>	<b>Lab Report Ref. No.</b>	<b>2224/005/02</b>
<b>Customer PO</b>		<b>Date of Receipt</b>	<b>22/02/2021</b>
<b>Customer Ref</b>	<i>Lisgall,Carrickmacross</i>	<b>Sampled On</b>	<b>22/02/2021</b>
<b>Ref 2</b>	<i>E283681/N306753</i>	<b>Date Testing Commenced</b>	<b>22/02/2021</b>
<b>Ref 3</b>	<i>Investigative/Donaghmoyne GWS/2400PRI2013</i>	<b>Received or Collected</b>	<b>By Fitz: Pick up DS</b>
		<b>Condition on Receipt</b>	<b>Acceptable</b>
		<b>Date of Report</b>	<b>10/03/2021</b>
		<b>Sample Type</b>	<b>Drinking Water</b>

## CERTIFICATE OF ANALYSIS

Test Parameter	SOP	Analytical Technique	Limit	Result	Units	Acc.
Manganese (Potable)	177	ICPMS	50	31	ug/L	UKAS

**Signed :**   
**Aoife Harmon - Laboratory Supervisor**

Page 1 of 1

**Date : 10/03/2021**

Acc. : Accredited Parameters by ISO/IEC 17025:2017

PVL - Parametric Value Limit as per EU (Drinking water) Regulations (SI 122 2014)

For bacterial analysis a result of 0 means none detected in volume examined

All organic results are analysed as received and all results are corrected for dry weight at 104 C

Results shall not be reproduced, except in full, without the approval of Fitz Scientific

Results contained in this report relate only to the samples tested (P) : Presumptive Results

\*\* : The test result for this parameter may be invalid as it has exceeded the recommended holding time (BS EN ISO 5667-3:2018)

