

A copy of this certificate is available on www.fitzsci.ie

Customer supplied information appear in italics.

Customer	<i>Dermot McCague</i> <i>Monaghan Co. Co. GWS</i> <i>Glen Road</i>	Lab Report Ref. No.	<i>2224/005/01</i>
		Date of Receipt	<i>22/02/2021</i>
		Sampled On	<i>22/02/2021</i>
		Date Testing Commenced	<i>22/02/2021</i>
	<i>Monaghan, H18 YT50</i>	Received or Collected	<i>By Fitz: Pick up DS</i>
Customer PO		Condition on Receipt	<i>Acceptable</i>
Customer Ref	<i>Drumcrew, Castleblayney</i>	Date of Report	<i>10/03/2021</i>
Ref 2	<i>E283311/N317621</i>	Sample Type	<i>Drinking Water</i>
Ref 3	<i>Investigative/Donaghmoyne GWS/2400PRI2013</i>		

CERTIFICATE OF ANALYSIS

Test Parameter	SOP	Analytical Technique	Limit	Result	Units	Acc.
Manganese (Potable)	177	ICPMS	50	30	ug/L	UKAS

Signed : 
Aoife Harmon - Laboratory Supervisor

Page 1 of 1

Date : 10/03/2021

Acc. : Accredited Parameters by ISO/IEC 17025:2017

PVL - Parametric Value Limit as per EU (Drinking water) Regulations (SI 122 2014)

For bacterial analysis a result of 0 means none detected in volume examined

All organic results are analysed as received and all results are corrected for dry weight at 104 C

Results shall not be reproduced, except in full, without the approval of Fitz Scientific

Results contained in this report relate only to the samples tested (P) : Presumptive Results

** : The test result for this parameter may be invalid as it has exceeded the recommended holding time (BS EN ISO 5667-3:2018)

