

A copy of this certificate is available on www.fitzsci.ie

Customer supplied information appear in italics.

<b>Customer</b>	<b>Dermot McCague</b> <b>Monaghan Co. Co. GWS</b> <b>Glen Road</b>	<b>Lab Report Ref. No.</b>	<b>2224/010/05</b>
		<b>Date of Receipt</b>	<b>17/05/2021</b>
		<b>Sampled On</b>	<b>17/05/2021</b>
		<b>Date Testing Commenced</b>	<b>17/05/2021</b>
		<b>Received or Collected</b>	<b>By Fitz: Pick up DS</b>
	<b>Monaghan, H18 YT50</b>	<b>Condition on Receipt</b>	<b>Acceptable</b>
<b>Customer PO</b>		<b>Date of Report</b>	<b>27/05/2021</b>
<b>Customer Ref</b>	<b>Kiosk Enagh Carrickmacross</b>	<b>Sample Type</b>	<b>Drinking Water</b>
<b>Ref 2</b>	<b>E280094/N398962</b>		
<b>Ref 3</b>	<b>Check/Magheraclone GWS/2400PRI2019</b>		

## CERTIFICATE OF ANALYSIS

Test Parameter	SOP	Analytical Technique	Limit	Result	Units	Acc.
Aluminium (Potable Water)	177	ICPMS	200	28	ug/L	UKAS
*Chlorine (Free)*	0	By Subcontractor	0.1	0.04	mg/L	
*Chlorine (Total)*	0	By Subcontractor	0.1	0.2	mg/L	
Coliforms Total (Potable)C	157	Filtration/Incubation	0	0	cfu/100ml	UKAS
Colour Apparent (Potable Water)	108	Colorimetry	-	<11	PtCo Units	UKAS
Conductivity (Potable Water at 20C)	112	Electrometry	2500	169.8	µscm -1@20C	UKAS
E. coli (Potable)C	157	Filtration/Incubation	0	0	cfu/100ml	UKAS
Iron (Potable Water)	177	ICPMS	200	<14	ug/L	UKAS
Odour	239	Olfactory Panel	-	1	TON	
pH (Potable Water)	110	Electrometry	6.5 - 9.5	7.95	pH Units	UKAS
Taste	238	Taste Panel	-	No Taste	FTN	
TBC @ 22°C (Potable)	493	Spread plate/Incubation	100	3	cfu/mL	UKAS
*Temperature (On site)*	0	By Subcontractor	-	10.8	degree C	
Turbidity (Potable Water)	109	Turbidimetry	-	0.1	NTU	UKAS

**Signed :**   
**Aoife Harmon - Laboratory Supervisor**

Page 1 of 1

**Date : 27/05/2021**

Acc. : Accredited Parameters by ISO/IEC 17025:2017

PVL - Parametric Value Limit as per EU (Drinking water) Regulations (SI 122 2014)

For bacterial analysis a result of 0 means none detected in volume examined

All organic results are analysed as received and all results are corrected for dry weight at 104 C

Results shall not be reproduced, except in full, without the approval of Fitz Scientific

Results contained in this report relate only to the samples tested (P) : Presumptive Results

\*\* : The test result for this parameter may be invalid as it has exceeded the recommended holding time (BS EN ISO 5667-3:2018)



\* Subcontracted

Final results will be issued without any estimated uncertainty of measurement being applied. This can be supplied on request.

Fitz Scientific maintain all customer information in the strictest confidence which is legally enforceable.