


Customer supplied information appear in italics.

Customer	<i>John Quinn Monaghan Co. Co. GWS Glen Road</i>	Lab Report Ref. No.	<i>2224/061/01</i>
		Date of Receipt	<i>07/07/2022</i>
		Sampled On	<i>07/07/2022</i>
		Date Testing Commenced	<i>07/07/2022</i>
		Received or Collected	<i>By Fitz: Pick up DF</i>
	<i>Monaghan, H18 YT50</i>	Condition on Receipt	<i>Acceptable</i>
Customer PO		Date of Report	<i>20/07/2022</i>
Customer Ref	<i>2400 PRI 2023 @SWS Office</i>	Sample Type	<i>Drinking Water</i>
Ref 2	<i>E257258/N340422</i>		
Ref 3	<i>Check</i>		

CERTIFICATE OF ANALYSIS

Test Parameter	SOP	Analytical Technique	Limit	Result	Units	Acc.
Chlorine (Free)	0	By Subcontractor	0.1	1.4	mg/L	
Chlorine (Total)	0	By Subcontractor	0.1	1.6	mg/L	
Coliforms Total (Potable)C	157	Filtration / Incubation	0	0	cfu/100ml	INAB
E. coli (Potable)C	157	Filtration / Incubation	0	0	cfu/100ml	INAB
TBC @ 22°C (Potable)	493	Spread plate / Incubation	100	38	cfu/mL	INAB
Temperature (On site)	0	By Subcontractor	-	15	degree C	

Signed:



Date: 20/07/2022

Aoife Harmon - Laboratory Supervisor

Acc. : Accredited Parameters by ISO/IEC 17025:2017

Limit as per Monaghan Co Co

For bacterial analysis a result of 0 means none detected in volume examined

All organic results are analysed as received and all results are corrected for dry weight at 104 C

Results shall not be reproduced, except in full, without the approval of Fitz Scientific

Results contained in this report relate only to the samples tested (P) : Presumptive Results

** : The test result for this parameter may be invalid as it has exceeded the recommended holding time (BS EN ISO 5667-3:2018)

* Subcontracted *

Final results will be issued without any estimated uncertainty of measurement being applied. This can be supplied on request.

Fitz Scientific maintain all customer information in the strictest confidence which is legally enforceable.

