

Unit 35, Boyne Business Park, Drogheda, Co. Louth, Ireland

Tel: +353 41 9845440 Fax: +353 41 9846171 Web: www.fitzsci.ie Email: info@fitzsci.ie

Customer supplied information appear in italics.

Customer John Quinn

Monaghan Co. Co. GWS

Glen Road

Lab Report Ref. No.
Date of Receipt
Sampled On
Date Testing Commenced

29/08/2022 29/08/2022 29/08/2022

2224/077/01

Received or Collected
Condition on Receipt

By Fitz: Pick up Acceptable 12/09/2022

Monaghan,H18 YT50

Customer PO Customer Ref

Ref 2

Stranooden GWS

Date of Report Sample Type

Drinking Water

Ref 3 Check/Stranooden/2400PRI2021

CERTIFICATE OF ANALYSIS

Test Parameter	SOP	Analytical Technique	Limit	Result	Units	Acc.
Aluminium (Potable Water)	177	ICPMS	200	117	ug/L	INAB
Coliforms Total (Potable)C	157	Filtration / Incubation	0	0	cfu/100ml	INAB
Colour Apparent (Potable Water)	108	Colorimetry	-	<11	PtCo Units	INAB
Conductivity (Potable Water at 20C)	112	Electrometry	2500	311.0	µscm -1@20C	INAB
E. coli (Potable)C	157	Filtration / Incubation	0	0	cfu/100ml	INAB
Iron (Potable Water)	177	ICPMS	200	<14	ug/L	INAB
Odour	239	Olfactory Panel	-	No Odour	TON	
pH (Potable Water)	110	Electrometry	6.5 - 9.5	7.30	pH Units	INAB
Taste	238	Taste Panel	-	1	FTN	
TBC @ 22°C (Potable)	493	Spread plate / Incubation	100	15	cfu/mL	INAB
Turbidity (Potable Water)	109	Turbidimetry	-	<0.1	NTU	INAB

Signed: A Hovemen

Aoife Harmon - Laboratory Supervisor

Acc.: Accredited Parameters by ISO/IEC 17025:2017

Limit as per Monaghan Co Co

For bacterial analysis a result of 0 means none detected in volume examined All organic results are analysed as received and all results are corrected for dry weight at 104 C Results shall not be reproduced, except in full, without the approval of Fitz Scientific Results contained in this report relate only to the samples tested (P): Presumptive Results

IIAC-MRA

Date: 12/09/2022



^{**:} The test result for this parameter may be invalid as it has exceeded the recommended holding time (BS EN ISO 5667-3:2018)

Final results will be issued without any estimated uncertainty of measurement being applied. This can be supplied on request. Fitz Scientific maintain all customer information in the strictest confidence which is legally enforceable.