

24-37958 Rev 0 Page 1 of 2 Report No.

Certificate of Analysis

Customer: Monaghan County Council Site/Project: Check

31/01/2024 Date Received: The Glen, Glen Rd, Tirkeenan, Monaghan **Local Authority:** Condition of Sample(s): Satisfactory

Customer Contact: Suzanne Clinton 31/01/2024 - 06/02/2024 Date Analysed:

Customer PO Issue Date: 14/02/2024

BATCH NUMBER: Quote No. 24-37958

Total Company

Jake Grunfield **Laboratory Analyst**

Index to symbols used:

| * | Analysis is not INAB accredited | | | | |
|-----|---------------------------------------------------------------------------------------------------------------|--|--|--|--|
| ** | Adapted from Standard Methods for the Examination of Water and Wastewater. | | | | |
| *** | S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023 | | | | |
| (F) | Analysis carried out at our Farranfore Laboratory. | | | | |
| (D) | Analysis carried out at our Dunrine Laboratory. | | | | |
| LOD | Parameter Limit of Quantification | | | | |

Notes

| Note A | The water should not be aggressive. | | | |
|--------|---------------------------------------------------------------------------------------|--|--|--|
| Note C | Acceptable to customers and no abnormal change. | | | |
| Note D | In the case of surface water treatment, a parametric value not exceeding 1 NTU in the | | | |
| | water ex treatment works must be strived for. | | | |
| Note E | Irish water parametric limit for TVC is <100 cfu/mL. | | | |
| Note F | Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L. | | | |
| Note 6 | Subcontracted Parameter. | | | |

- The results relate only to the items tested.
- Opinions and interpretations expressed herein are outside the scope of INAB accreditation.
- The analysis report shall not be reproduced except in full without written approval of the laboratory.
- Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022







Report No. 24-37958 Rev 0 Page 2 of 2

Customer Sample Ref: Mace, Magheracloone, Co Monaghan, A81

KR80. - Deli sink.

Customer Sample Code:

Entity Code:

Sample Condition:

Satisfactory

Entity Name: Site / Project: Magheracloone GWS

Check

ck Sampled By:

MON CoCo

Our Reference: Date Sampled:

117636 (24-37958) -31/01/2024 Sample Matrix: Drinking Water
Time Sampled: 09:20

| Method: | | Parameter: | Units | LOQ | Result | ***Limits |
|---------------|---|-----------------------------------------------------|--------------|------|--------|-------------|
| | | Onsite Measurements: | | | | |
| SEP 007 | * | Temperature | °C | | 7.60 | |
| SEP 007 | * | Free Chlorine | mg/L | 0.02 | 0.49 | |
| SEP 007 | * | Total Chlorine <u>Microbiological Analysis: (D)</u> | mg/L | 0.02 | 0.65 | |
| SMP 019 | | Coliforms | MPN/100mL | <1 | < 1 | |
| SMP 019 | | E. coli | MPN/100mL | <1 | < 1 | |
| SMP 061 | | TVC @ 22°C for 72 Hrs | cfu/mL | <1 | 1 | cfu/mL |
| SMP 068 | | Enterococci Chemical Analysis: (F) | MPN/100mL | <1 | < 1 | |
| SCP 052 | | Hydrogen Ion (pH) | pH units | 4.0 | 8.0 | pH (Note A) |
| SCP 052 | | Conductivity | μS/cm @ 20 ℃ | 15 | 158 | |
| SCP 058/058B | | Turbidity | NTU | 0.20 | < 0.20 | Note C & D |
| SCP 018/018B | | Apparent Colour | Pt-Co | 5 | 12 | Note C |
| SCP 053B/053D | | Aluminium | μg/L | 10 | < 10 | |
| SCP 053B/053D | | Iron | μg/L | 10 | 16 | |
| SCP 053B/053D | | Manganese | μg/L | 2 | < 2 | |
| SCP 082 | * | Odour | - | | 0 | Note C |
| **2160B | * | Taste | - | | 0 | Note C |

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

