

**Report No.** 24-38622 Rev 0 Page 1 of 2

## **Certificate of Analysis**

Customer: Monaghan County Council Site/Project: Check

Local Authority: The Glen, Glen Rd, Tirkeenan, Monaghan

Date Received: 16/02/2024

Condition of Sample(s): Satisfactory

Customer Contact: Suzanne Clinton Date Analysed: 16/02/2024 - 21/02/2024

Customer PO Issue Date: 27/02/2024

Quote No. BATCH NUMBER: 24-38622

Jake Grunfield

**Laboratory Analyst** 

Total Company

## Index to symbols used:

*	Analysis is not INAB accredited				
**	Adapted from Standard Methods for the Examination of Water and Wastewater.				
***	S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023				
(F)	Analysis carried out at our Farranfore Laboratory.				
(D)	Analysis carried out at our Dunrine Laboratory.				
LOD	Parameter Limit of Quantification				

## **Notes**

Note A	The water should not be aggressive.				
Note C	Acceptable to customers and no abnormal change.				
Note D	In the case of surface water treatment, a parametric value not exceeding 1 NTU in the				
	water ex treatment works must be strived for.				
Note E	Irish water parametric limit for TVC is <100 cfu/mL.				
Note F	Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L.				
Note 6	Subcontracted Parameter.				

- The results relate only to the items tested.
- Opinions and interpretations expressed herein are outside the scope of INAB accreditation.
- The analysis report shall not be reproduced except in full without written approval of the laboratory.
- · Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022







**Report No.** 24-38622 Rev 0 Page 2 of 2

Customer Sample Ref: Millford Furniture, Davagh Etra, Emyvale, H18 Customer Sample Code:

KW89. - Canteen sink.

Sample Condition: Satisfactory

Entity Name: Truagh GWS Entity Code:

Site / Project:CheckSampled By:Katie Brady, SSS, LTD.Our Reference:119572 (24-38622) -Sample Matrix:Drinking WaterDate Sampled:16/02/2024Time Sampled:10:20

Method:		Parameter:	Units	LOQ	Result	***Limits
		Onsite Measurements:				
SEP 007	*	Temperature	°C		7.30	
SEP 007	*	Free Chlorine	mg/L	0.02	0.50	
SEP 007	*	Total Chlorine	mg/L	0.02	0.63	
		Microbiological Analysis: (D)				
SMP 019		Coliforms	MPN/100mL	<1	< 1	0 MPN/100mL
SMP 019		E. coli	MPN/100mL	<1	< 1	0 MPN/100mL
SMP 061		TVC @ 22°C for 72 Hrs	cfu/mL	<1	< 1	<= 100 cfu/mL
SMP 068		Enterococci	MPN/100mL	<1	< 1	0 MPN/100mL
		Chemical Analysis: (F)				
SCP 052		Hydrogen Ion (pH)	pH units	4.0	7.2	6.5 - 9.5pH (Note A)
SCP 052		Conductivity	μS/cm @ 20 ℃	15	107	2500 μS/cm @ 20 ℃
SCP 058/058B		Turbidity	NTU	0.20	< 0.20	Note C & D
SCP 018/018B		Apparent Colour	Pt-Co	5	< 5	Note C
SCP 053B/053D		Aluminium	μg/L	10	62	200 μg/L
SCP 053B/053D		Iron	μg/L	10	20	200 μg/L
SCP 053B/053D		Manganese	μg/L	2	< 2	50 μg/L
SCP 082	*	Odour	-		0	Note C
**2160B	*	Taste	-		0	Note C



4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

