

Report No. 24-40009 Rev 0 Page 1 of 2

Certificate of Analysis

Customer: Monaghan County Council Site/Project: Check

Local Authority: The Glen, Glen Rd, Tirkeenan, Monaghan

Date Received: 22/03/2024

Condition of Sample(s): Satisfactory

Customer Contact: Suzanne Clinton Date Analysed: 22/03/2024 - 03/04/2024

Customer PO Issue Date: 17/04/2024

Quote No. BATCH NUMBER: 24-40009

Jake Grunfield

Laboratory Analyst

Total Company

Index to symbols used:

*	Analysis is not INAB accredited
**	Adapted from Standard Methods for the Examination of Water and Wastewater.
***	S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023
(F)	Analysis carried out at our Farranfore Laboratory.
(D)	Analysis carried out at our Dunrine Laboratory.
LOD	Parameter Limit of Quantification

Notes

Note A	The water should not be aggressive.
Note C	Acceptable to customers and no abnormal change.
Note D	In the case of surface water treatment, a parametric value not exceeding 1 NTU in the
	water ex treatment works must be strived for.
Note E	Irish water parametric limit for TVC is <100 cfu/mL.
Note F	Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L.
Note 6	Subcontracted Parameter.

- The results relate only to the items tested.
- Opinions and interpretations expressed herein are outside the scope of INAB accreditation.
- The analysis report shall not be reproduced except in full without written approval of the laboratory.
- · Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022







Report No. 24-40009 Rev 0 Page 2 of 2

Customer Sample Ref: Costcutter, Lisdoonan, A81RX47. - Deli sink. Customer Sample Code:

22/03/2024

Sample Condition: Satisfactory

10:50

0

Entity Name: Donaghmoyne GWS Entity Code:

Site / Project:CheckSampled By:Katie Brady, SSS, LTD.Our Reference:123716 (24-40009) -Sample Matrix:Drinking Water

Time Sampled:

Parameter: Units LOQ ***Limits Method: Result Onsite Measurements: **SEP 007** Temperature °C 9.40 **SEP 007** Free Chlorine 0.02 0.70 mg/L **SEP 007 Total Chlorine** 0.02 1.07 mg/L Microbiological Analysis: (D) SMP 019 MPN/100mL < 1 0 MPN/100mL Coliforms <1 SMP 019 MPN/100mL 0 MPN/100mL E. coli < 1 <1 SMP 061 TVC @ 22°C for 72 Hrs <= 100 cfu/mL cfu/mL < 1 <1 SMP 068 MPN/100mL 0 MPN/100mL Enterococci <1 < 1 Chemical Analysis: (F) 6.5 - 9.5pH (Note A) SCP 052 Hydrogen Ion (pH) pH units 4.0 7.1 µS/cm @ 20 °C 2500 µS/cm @ 20 ℃ SCP 052 Conductivity 15 160 NTU Note C & D SCP 058/058B Turbidity 0.20 < 0.20 SCP 018/018B Apparent Colour Pt-Co 5 < 5 Note C SCP 053B/053D Aluminium μg/L 10 < 10 $200 \mu g/L$ SCP 053B/053D Iron μg/L 10 < 10 200 μg/L SCP 053B/053D Manganese μg/L 2 < 2 50 μg/L SCP 082 Odour 0 Note C



Date Sampled:

**2160B

Taste

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022



Note C