

24-49056 Report No.

Page 1 of 2

Certificate of Analysis

Customer:	Monaghan County Council	Site/Project:	Check	
	The Glen, Glen Rd, Tirkeenan, Monaghan	Date Received:	14/10/2024	
Local Authority:		Condition of Sample(s):	Satisfactory	
Customer Contact: Suzanne Clinton		Date Analysed:	14/10/2024 - 01/11/2024	
Customer PO		Issue Date:	19/11/2024	
Quote No.		BATCH NUMBER:	24-49056	

Jone Comful

Jake Grunfield Laboratory Analyst

Index to symbols used:

*	Analysis is not INAB accredited
**	Adapted from Standard Methods for the Examination of Water and Wastewater.
***	S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023
(F)	Analysis carried out at our Farranfore Laboratory.
(D)	Analysis carried out at our Dunrine Laboratory.
LÓD	Parameter Limit of Quantification

Notes

Note A	The water should not be aggressive.		
Note C	Acceptable to customers and no abnormal change.		
Note D	In the case of surface water treatment, a parametric value not exceeding 1 NTU in the		
	water ex treatment works must be strived for.		
Note E	Irish water parametric limit for TVC is <100 cfu/mL.		
Note F	Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L.		
Note 6	Subcontracted Parameter.		

- The results relate only to the items tested.
- Opinions and interpretations expressed herein are outside the scope of INAB accreditation. ٠
- The analysis report shall not be reproduced except in full without written approval of the laboratory.
- Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022



web site www.southernscientificireland.com | e-mail info@southernscientificireland.com

directors: K. Murphy, M. Murphy & C. Murphy registered in ireland no 323196 | vat reg no IE 6343196 M



Rev 0

24-49056

Report No.

•							0	
Customer Sample Ref:Doohamlet, Dernaglug A75 EF99 reception areaEntity Name:Doohamlet GWSSite / Project:CheckOur Reference:148954 (24-49056) -Date Sampled:14/10/2024		0 0	ink in Customer Sample Code:					
		rec	reception area		Sample Condition: Entity Code:		Satisfactory	
		hamlet GWS	Entity Code:					
		Check	sampled By		Declan Callan SSS Ltd			
		14895	148954 (24-49056) -		Sample Matrix:		Drinking Water	
		14/10/2024		Time Sampled:		12:30		
Method:		Parameter:	Units		LOQ	Result	***Limits	
		Onsite Measurements:						
SEP 007	*	Temperature	°C			14.40		
SEP 007	*	Free Chlorine	mg/L		0.02	1.06		
SEP 007	*	Total Chlorine <u>Microbiological Analysis: (D)</u>	mg/L		0.02	1.16		
SMP 019		Coliforms	MPN/1	00mL	<10	< 1	0 MPN/100mL	
SMP 019		E. coli	MPN/1	00mL	<10	< 1	0 MPN/100mL	
SMP 061		TVC @ 22°C for 72 Hrs	cfu/mL		<1	< 1	<= 100 cfu/mL	
SMP 068		Enterococci Chemical Analysis: (F)	MPN/1	00mL	<1	< 1	0 MPN/100mL	
SCP 052		Hydrogen Ion (pH)	pH uni	ts	4.0	7.3	6.5 - 9.5pH (Note A)	
SCP 052		Conductivity	μS/cm	@ 20 ℃	14.7	320.0	2500.0 µS/cm @ 20	
SCP 058/058B		Turbidity	NTU		0.20	< 0.20	Note C & D	
SCP 018/018B		Apparent Colour	Pt-Co		5	< 5	Note C	
SCP 053B/053D		Aluminium	μg/L		10	184	200 μg/L	
SCP 053B/053D		Iron	μg/L		10	13	200 μg/L	
SCP 053B/053D		Manganese	μg/L		2	< 2	50 μg/L	
SCP 082	*	Odour	-			0	Note C	

(registered office)

**2160B

Taste

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

web site www.southernscientificireland.com | e-mail info@southernscientificireland.com

directors: K. Murphy, M. Murphy & C. Murphy registered in ireland no 323196 | vat reg no IE 6343196 M



Note C

0

Page 2 of 2