

Report No. 24-52143

Rev 0

Page 1 of 2

## Certificate of Analysis

Customer:	Monaghan County Council	Site/Project:	Check	
		Date Received:	20/12/2024	
Local Authority:	The Glen, Glen Rd, Tirkeenan, Monaghan	Condition of Sample(s):	Satisfactory	
Customer Contact:	Suzanne Clinton	Date Analysed:	20/12/2024 - 02/01/2025	
Customer PO		Issue Date:	13/01/2025	
Quote No.		BATCH NUMBER:	24-52143	

Jone Comfiel

Jake Grunfield Laboratory Analyst

## Index to symbols used:

*	Analysis is not INAB accredited
**	Adapted from Standard Methods for the Examination of Water and Wastewater.
***	S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023
(F)	Analysis carried out at our Farranfore Laboratory.
(D)	Analysis carried out at our Dunrine Laboratory.
LOD	Parameter Limit of Quantification

## Notes

Note A	The water should not be aggressive.
Note C	Acceptable to customers and no abnormal change.
Note D	In the case of surface water treatment, a parametric value not exceeding 1 NTU in the
	water ex treatment works must be strived for.
Note E	Irish water parametric limit for TVC is <100 cfu/mL.
Note F	Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L.
Note 6	Subcontracted Parameter.

- The results relate only to the items tested.
- Opinions and interpretations expressed herein are outside the scope of INAB accreditation.
- The analysis report shall not be reproduced except in full without written approval of the laboratory.
- Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022



web site www.southernscientificireland.com | e-mail info@southernscientificireland.com

directors: K. Murphy, M. Murphy & C. Murphy registered in ireland no 323196 | vat reg no IE 6343196 M



Rev 0

Report No. 24-52143

Entity Name:AughnashSite / Project:ChOur Reference:157246 (2)		kitchen sink		Customer Sample Code:				
				Sample Condition:		Sat	Satisfactory	
		Aughnashalvey	Aughnashalvey GWS Entity Code: Check Sampled By:			Declan Callan, SSS Ltd		
		Check			Sampled By:			
		157246 (24-52143) - 20/12/2024		Sample Matrix: Time Sampled:		Drink	Drinking Water 10:30	
Method:		Parameter:	Units		LOQ	Result	***Limits	
		Onsite Measurements:						
SEP 007	*	Temperature	°C			8.10		
SEP 007	*	Free Chlorine	mg/L		0.02	0.44		
SEP 007	*	Total Chlorine	mg/L		0.02	0.63		
		Microbiological Analysis: (D)						
SMP 019		Coliforms	MPN/1	00mL	<1	< 1	0 MPN/100mL	
SMP 061		TVC @ 22°C for 72 Hrs	cfu/mL	_	<1	< 1	<= 100 cfu/mL	
SMP 019		E. coli	MPN/1	00mL	<1	< 1	0 MPN/100mL	
SMP 068		Enterococci	MPN/1	00mL	<1	< 1	0 MPN/100mL	
		Chemical Analysis: (F)						
SCP 052		Hydrogen Ion (pH)	pH uni		4.0	7.5	6.5 - 9.5pH (Note A)	
SCP 052		Conductivity		@ 20 °C	14.7	323.0	2500.0 µS/cm @ 20	
SCP 058/058B		Turbidity	NTU		0.20	< 0.20	Note C & D	
SCP 018/018B		Apparent Colour	Pt-Co		5	6	Note C	
SCP 082	*	Odour	-			0	Note C	
**2160B	*	Taste	-			0	Note C	
SCP 053B/053D		Aluminium	μg/L		10	< 10	200 μg/L	
SCP 053B/053D		Iron	μg/L		10	80	200 μg/L	
SCP 053B/053D		Manganese	μg/L		2	< 2	50 μg/L	

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

web site www.southernscientificireland.com | e-mail info@southernscientificireland.com

directors: K. Murphy, M. Murphy & C. Murphy registered in ireland no 323196 | vat reg no IE 6343196 M



Page 2 of 2