

Report No. 25-02993 Rev 0 Page 1 of 2

Certificate of Analysis

Customer: Monaghan County Council Site/Project: Check

Local Authority: The Glen, Glen Rd, Tirkeenan, Monaghan

Date Received: 07/03/2025

Condition of Sample(s): Satisfactory

Customer Contact: Suzanne Clinton Date Analysed: 07/03/2025 - 18/03/2025

Customer PO Issue Date: 25/03/2025

Quote No. Q24-00640 **BATCH NUMBER: 25-02993**

Jake Grunfield

Laboratory Analyst

Inte Carpet

Index to symbols used:

*	Analysis is not INAB accredited
**	Adapted from Standard Methods for the Examination of Water and Wastewater.
***	S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023
(F)	Analysis carried out at our Farranfore Laboratory.
(D)	Analysis carried out at our Dunrine Laboratory.
LOD	Parameter Limit of Quantification

Notes

Note A	The water should not be aggressive.				
Note C	Acceptable to customers and no abnormal change.				
Note D	In the case of surface water treatment, a parametric value not exceeding 1 NTU in the				
	water ex treatment works must be strived for.				
Note E	Irish water parametric limit for TVC is <100 cfu/mL.				
Note F	Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L.				
Note 6	Subcontracted Parameter.				

- ◆ The results relate only to the items tested.
- Opinions and interpretations expressed herein are outside the scope of INAB accreditation.
- The analysis report shall not be reproduced except in full without written approval of the laboratory.
- · Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022







Report No. 25-02993 Rev 0

Customer Sample Ref: Scoil Phadraig, Corduff, Carrickmacross

A81PP78 - staffroom sink

Customer Sample Code:

Sample Condition:

Satisfactory

Entity Name:

Corduff GWS

Check

Sampled By:

Entity Code:

Declan Callan, SSS Ltd

Site / Project:
Our Reference:

166187 (25-02993) -

Sample Matrix:

Drinking Water

Date Sampled: 07/03/2025

Time Sampled: 09:30

Method:		Parameter:	Units	LOQ	Result	***Limits
		Onsite Measurements:				
SEP 007	*	Temperature	°C		9.00	
SEP 007	*	Free Chlorine	mg/L	0.02	0.55	
SEP 007	*	Total Chlorine Microbiological Analysis: (D)	mg/L	0.02	0.76	
SMP 019		Coliforms	MPN/100mL	<10	< 1	< 1 MPN/100mL
SMP 019		E. coli	MPN/100mL	<10	< 1	< 1 MPN/100mL
SMP 061		TVC @ 22°C for 72 Hrs	cfu/mL	<1	< 1	<= 100 cfu/mL
SMP 068		Enterococci Chemical Analysis: (F)	MPN/100mL	<1	< 1	< 1 MPN/100mL
SCP 052		Hydrogen Ion (pH)	pH units	4.0	7.6	6.5 - 9.5pH (Note A)
SCP 052		Conductivity	μS/cm @ 20 °C	14.7	241.0	2500.0 μS/cm @ 20
SCP 058/058B		Turbidity	NTU	0.20	< 0.20	Note C & D
SCP 018/018B		Apparent Colour	Pt-Co	5	< 5	Note C
SCP 053B/053D		Aluminium	μg/L	10	< 10	200 μg/L
SCP 053B/053D		Iron	μg/L	10	< 10	200 μg/L
SCP 053B/053D		Manganese	μg/L	2	< 2	50 μg/L
SCP 082	*	Odour	-		0	Note C
**2160B	*	Taste	-		0	Note C

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

