

25-02993 Rev 0 Page 1 of 2 Report No.

Certificate of Analysis

Customer: Monaghan County Council Site/Project: Check

07/03/2025 Date Received: The Glen, Glen Rd, Tirkeenan, Monaghan **Local Authority:** Condition of Sample(s): Satisfactory

Customer Contact: Suzanne Clinton 07/03/2025 - 18/03/2025 Date Analysed:

Customer PO Issue Date: 25/03/2025

BATCH NUMBER: Quote No. Q24-00640 25-02993

Jake Grunfield **Laboratory Analyst**

Inte Carpert

Index to symbols used:

*	Analysis is not INAB accredited
**	Adapted from Standard Methods for the Examination of Water and Wastewater.
***	S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023
(F)	Analysis carried out at our Farranfore Laboratory.
(D)	Analysis carried out at our Dunrine Laboratory.
LOD	Parameter Limit of Quantification

Notes

Note A	The water should not be aggressive.
Note C	Acceptable to customers and no abnormal change.
Note D	In the case of surface water treatment, a parametric value not exceeding 1 NTU in the
	water ex treatment works must be strived for.
Note E	Irish water parametric limit for TVC is <100 cfu/mL.
Note F	Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L.
Note 6	Subcontracted Parameter.

- The results relate only to the items tested.
- Opinions and interpretations expressed herein are outside the scope of INAB accreditation.
- The analysis report shall not be reproduced except in full without written approval of the laboratory.
- Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022







Report No. 25-02993 Rev 0 Page 2 of 2

Customer Sample Ref: 5 Cois Carraig, A75 FA40 Customer Sample Code:

Sample Condition: Satisfactory

Entity Name: Doohamlet GWS Entity Code:

Site / Project:CheckSampled By:Declan Callan, SSS LtdOur Reference:166189 (25-02993) -Sample Matrix:Drinking WaterDate Sampled:07/03/2025Time Sampled:11:50

Parameter: Units LOQ ***Limits Method: Result Onsite Measurements: **SEP 007** Temperature °C 10.20 **SEP 007** Free Chlorine 0.02 0.82 mg/L **SEP 007 Total Chlorine** 0.02 0.96 mg/L Microbiological Analysis: (D) SMP 019 Coliforms MPN/100mL <10 < 1 < 1 MPN/100mL SMP 019 MPN/100mL < 1 MPN/100mL E. coli <10 < 1 SMP 061 TVC @ 22°C for 72 Hrs <= 100 cfu/mL cfu/mL <1 < 1 SMP 068 MPN/100mL < 1 MPN/100mL Enterococci <1 < 1 Chemical Analysis: (F) SCP 052 6.5 - 9.5pH (Note A) Hydrogen Ion (pH) pH units 4.0 7.4 μS/cm @ 20 °C 2500.0 µS/cm @ 20 SCP 052 Conductivity 14.7 304.0 NTU Note C & D SCP 058/058B Turbidity 0.20 < 0.20 SCP 018/018B Apparent Colour Pt-Co 5 < 5 Note C SCP 053B/053D Aluminium μg/L 10 10 $200 \mu g/L$ SCP 053B/053D Iron μg/L 10 < 10 200 μg/L SCP 053B/053D Manganese μg/L 2 < 2 50 μg/L SCP 082 Odour 0 Note C 0 **2160B Taste Note C



4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

