

25-07200 Rev 0 Page 1 of 2 Report No.

## **Certificate of Analysis**

**Customer:** Monaghan County Council Site/Project: Investigative

26/05/2025 Date Received: The Glen, Glen Rd, Tirkeenan, Monaghan **Local Authority:** Condition of Sample(s): Satisfactory

**Customer Contact:** Suzanne Clinton 26/05/2025 - 29/05/2025 Date Analysed:

**Customer PO** Issue Date: 06/06/2025

**BATCH NUMBER:** Quote No. Q24-00640 25-07200

Jake Grunfield

**Laboratory Analyst** 

Inte Carpet

## Index to symbols used:

*	Analysis is not INAB accredited
**	Adapted from Standard Methods for the Examination of Water and Wastewater.
***	S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023
(F)	Analysis carried out at our Farranfore Laboratory.
(D)	Analysis carried out at our Dunrine Laboratory.
LOD	Parameter Limit of Quantification

## **Notes**

Note A	The water should not be aggressive.
Note C	Acceptable to customers and no abnormal change.
Note D	In the case of surface water treatment, a parametric value not exceeding 1 NTU in the
	water ex treatment works must be strived for.
Note E	Irish water parametric limit for TVC is <100 cfu/mL.
Note F	Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L.
Note 6	Subcontracted Parameter.

- The results relate only to the items tested.
- Opinions and interpretations expressed herein are outside the scope of INAB accreditation.
- The analysis report shall not be reproduced except in full without written approval of the laboratory.
- Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022







**Report No.** 25-07200 Rev 0 Page 2 of 2

Customer Sample Ref: Naomh Michael NS, Donaghmoyne,

Carrickmacross, Monaghan A81EA37-staff

room sink

Entity Name: Donaghmoyne GWS

Site / Project: Investigative

Our Reference: 178098 (25-07200) -

**Date Sampled:** 26/05/2025

**Customer Sample Code:** 

Sample Condition: Satisfactory

Entity Code:

Time Sampled:

Sampled By: Declan Callan, SSS Ltd
Sample Matrix: Drinking Water

09:25

 Method:
 Parameter:
 Units
 LOQ
 Result
 \*\*\*Limits

 Chemical Analysis: (F)
 SCP 053B/053D
 Manganese
 μg/L
 2
 11
 50 μg/L

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589 dunrine | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

