

Certificate of Analysis

Customer:	Monaghan County Council	Site/Project:	Drinking Water
Local Authority:	The Glen, Glen Rd, Tirkeenan, Monaghan	Date Received:	03/06/2026
Customer Contact:	Suzanne Clinton	Condition of Sample(s):	Satisfactory
Customer PO		Date Analysed:	03/06/2026 - 15/06/2026
Quote No.	Q26-01675	Issue Date:	18/06/2026
		BATCH NUMBER:	26-08736

Joanne O'Halloran

Joanne O'Halloran
Deputy Laboratory Manager

Index to symbols used:

*	Analysis is not INAB accredited
**	Adapted from Standard Methods for the Examination of Water and Wastewater.
***	S.I. No. 122 of 2014 and S.I No. 99 of 2023 - European Union (Drinking Water) Regulations 2014, 2017 and 2023
(F)	Analysis carried out at our Farranfore Laboratory.
(D)	Analysis carried out at our Dunrinc Laboratory.
LOD	Parameter Limit of Quantification

Notes

Note A	The water should not be aggressive.
Note C	Acceptable to customers and no abnormal change.
Note D	In the case of surface water treatment, a parametric value not exceeding 1 NTU in the water ex treatment works must be strived for.
Note E	Irish water parametric limit for TVC is <100 cfu/mL.
Note F	Fluoridated supplies 0.8 mg/L; Natural supplies 1.5 mg/L.
Note 6	Subcontracted Parameter.

- ◆ The results relate only to the items tested.
- ◆ Opinions and interpretations expressed herein are outside the scope of INAB accreditation.
- ◆ The analysis report shall not be reproduced except in full without written approval of the laboratory.
- ◆ Sampling is outside the scope of the laboratory activities.

(registered office)

4 park business centre | farranfore | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589
dunrinc | killarney | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

web site www.southernscientificireland.com | e-mail info@southernscientificireland.com

directors: K. Murphy, M. Murphy & C. Murphy
registered in ireland no 323196 | vat reg no IE 6343196 M





Customer Sample Ref:	Lisdoonan NS - Staffroom sink, Lisdoonan, Carrickmacross, Monaghan A81WR65	Customer Sample Code:	
Entity Name:	Donaghmoyne GWS	Sample Condition:	Satisfactory
Site / Project:	Regulatory (Check)	Entity Code:	
Our Reference:	241592 (26-08736) -	Sampled By:	Declan SSS
Date Sampled:	03/06/2026	Sample Matrix:	Drinking Water
		Time Sampled:	09:45

Method:	Parameter:	Units	LOQ	Result	***Limits
<u>Onsite Measurements:</u>					
SEP 007	* Temperature	°C		14.50	
SEP 007	* Free Chlorine	mg/L	0.02	0.20	
SEP 007	* Total Chlorine	mg/L	0.02	0.44	
<u>Microbiological Analysis: (D)</u>					
SMP 019	Coliforms	MPN/100mL	<1	< 1	< 1 MPN/100mL
SMP 061	TVC @ 22°C for 72 Hrs	cfu/mL	<1	< 1	<= 100 cfu/mL
SMP 019	E. coli	MPN/100mL	<1	< 1	< 1 MPN/100mL
SMP 068	Enterococci	MPN/100mL	<1	< 1	< 1 MPN/100mL
<u>Chemical Analysis: (F)</u>					
SCP 052	Hydrogen Ion (pH)	pH units	4.0	7.3	6.5 - 9.5pH (Note A)
SCP 052	Conductivity	µS/cm @ 20 °C	14.7	187.0	2500.0 µS/cm @ 20
SCP 058/058B	Turbidity	NTU	0.20	< 0.20	Note C & D
SCP 018/018B	Apparent Colour	Pt-Co	5	< 5	Note C
SCP 082	* Odour	-		0	Note C
SCP 082	* Taste	-		0	Note C
SCP 053B/053D	Aluminium	µg/L	10	11	200 µg/L
SCP 053B/053D	Iron	µg/L	10	< 10	200 µg/L
SCP 053B/053D	Manganese	µg/L	2	3	50 µg/L

(registered office)

4 park business centre | **farranfore** | county kerry | ireland | telephone +353 66 976 3588 | fax +353 66 976 3589
dunrune | **killarney** | county kerry | ireland | telephone +353 64 66 33922 | fax +353 64 66 39022

web site www.southernscientificireland.com | e-mail info@southernscientificireland.com

directors: K. Murphy, M. Murphy & C. Murphy
registered in ireland no 323196 | vat reg no IE 6343196 M

